



Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Consultation Response - Your Ref AL/58/15/OUT

Our Ref
PLAN-012169

Date
07/01/2016

Dear Sirs,

Proposal: Hybrid Application 1: Full planning application for earth works to facilitate flood compensation area 2: Outline application (all matters reserved) for up to 20,453 sq m of B2 General Industrial Floorspace together with B8 warehousing & distribution floorspace.
Site: Oldlands Farm, Steyning Way, Bersted, PO22 9NN.
AL/58/15/OUT

Thank you for your letter of 09/12/2015.

Following initial investigations, Southern Water cannot accommodate the needs of this application without the development providing additional local infrastructure. The proposed development would increase flows into the wastewater sewerage system and as a result increase the risk of flooding in and around the existing area, contrary to paragraph 109 of the National Planning Policy Framework. Section 98 of the Water Industry Act 1991 provides a legal mechanism through which the appropriate infrastructure can be requested by the developer to accommodate the above mentioned proposal.

Should the Local Planning Authority be minded to approve the application, Southern Water would like the following condition to be attached to any permission. "Development shall not commence until a drainage strategy detailing the proposed means of foul and surface water disposal and a implementation timetable, has been submitted to and approved in writing by, the local planning authority in consultation with the sewerage undertaker. The development shall be carried out in accordance with the approved scheme and timetable."

We suggest the following informative: "The applicant/developer should enter into a formal agreement with Southern Water to provide the necessary sewerage

infrastructure required to service this development. Please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Our initial investigations indicate that Southern Water can provide surface water disposal to service the proposed development. Southern Water requires a formal application for a connection to the public surface water sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

"A formal application for connection to the public sewerage system is required in order to service this development. Please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk".

It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order

- a Adequate soakaway or infiltration system
- b Water course
- c Where neither of the above is practicable sewer

Southern Water supports this stance and seeks through appropriate Planning Conditions to ensure that appropriate means of surface water disposal are proposed for each development. It is important that discharge to sewer occurs only where this is necessary and where adequate capacity exists to serve the development. When it is proposed to connect to a public sewer the prior approval of Southern Water is required.

The planning application form makes reference to drainage using Sustainable Urban Drainage Systems (SUDS).

Under current legislation and guidance SUDS rely upon facilities which are not adoptable by sewerage undertakers. Therefore, the applicant will need to ensure that arrangements exist for the long term maintenance of the SUDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system. Thus, where a SUDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

Specify the responsibilities of each party for the implementation of the SUDS scheme
Specify a timetable for implementation
Provide a management and maintenance plan for the lifetime of the development. This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime.



The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

The application details for this development indicate that the proposed means of surface water drainage for the site is via a watercourse. The Council's technical staff and the relevant authority for land drainage consent should comment on the adequacy of the proposals to discharge surface water to the local watercourse.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul and surface water sewerage disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site. The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk

Yours sincerely

Developer Sen 

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved License No. W17 298230

O.S. REF: SU9401NW

Scale: 1:4825

Screen Print

WARNING: BAF pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (U/K) materials may include Bonded Asbestos Cement



Printed By: reddyma

Date: 30-12-2015

Southern Water MapGuide Browser

Requested By:



