Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning & Building Control General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail:planning@arun.gov.uk
website: www.arun.gov.uk/planning

Thakeham Partnerships Ltd
Thakeham House
Stane Street
Billingshurst
RH14 9GN

Date: 18th August 2023

Please ask for: Mr S Davis
Tel: 01903 737874

Your Ref:
Our Ref: AL/65/23/DOC

Dear Mr Flashman,

**Town & Country Planning Act 1990 (as amended)**
**Town and Country Planning (Development Management Procedure) (England) Order 2015**
**Approval of details reserved by condition imposed under ref AL/21/20/OUT relating to Conditions 9 - surface water drainage,10 - watercourses,11 - surface water drainage maintenance and management and 16 - foul drainage.**
**Land North of Lee's Yard Lidsey Road Woodgate PO20 3SU**

Notification regarding the above application:

**Condition Number 9**

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

**Decision:**

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

Please refer to the comments on our website dated 17/08/23. Given the outstanding information/issues to be resolved, it is not appropriate to allow an opportunity to amend the submission and this

application is refused. A resubmission is required.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely



Neil Crowther
Group Head of Planning