




From: Ian Wightman [REDACTED]
Sent: 24 July 2015 15:12
To: Simon Davis
Cc: Martyn White
Subject: RE: Planning Consultation on AL/66/15/DOC

Hi Simon,

Thank you for the details of the glazing. 14 or 16mm will be fine for the large doors at the rear however the windows should be 11-12mm.

With respect to Condition 5, I was querying the mortar in the existing brick wall, not the new render. If this wall is cement, then a vapour permeable approach may be compromised. This is more of an informative.

Hope that makes sense.

Ian

Ian Wightman
Senior Historic Buildings Adviser
Conservation and Design
Chichester District Council
Tel: 01243 785 166 | Fax: 01243 776766 | iwightman@chichester.gov.uk | <http://www.chichester.gov.uk>
www.facebook.com/ChichesterDistrictCouncil | www.twitter.com/ChichesterDC