

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 12 July 2021 12:57

To: James Cross <James.Cross@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: FW: Ryefields Farmhouse, Oak Tree Lane, Woodgate, Chichester, West Sussex, PO20 3GU - AL/81/21/PL

Planning Application Reference: AL/81/21/PL

Proposal: Demolition of existing building & erection of 5 No houses comprising 1 No 4-bed detached, 2 No 4-bed link detached & 2 No 3-bed detached houses with associated access & parking (resubmission following AL/72/19/PL). This site is in CIL Zone 1 & is Zero Rated.

Address: Ryefields Farmhouse, Oak Tree Lane, Woodgate, Chichester, West Sussex, PO20 3GU

Dear James,

Please see my further comment below.

Noise assessment – Woodgate autos

No information has been provided assessing the potential noise impact from nearby adjacent commercial uses including deliveries and plant / equipment.

I therefore recommend that in order for this section to make an informed comment the applicant should be requested to provide further information assessing the noise impact of the external noise sources on the proposed residential accommodation. The report should include, if appropriate, measures to be taken to mitigate excess noise impact.

The report should be prepared by a person with appropriate acoustic qualifications and should be with full regard to all relevant guidance including BS8233:2014 - Guidance on Sound Insulation and Noise Reduction for Buildings and BS4142:2014 Methods for rating and assessing industrial and commercial sound.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)



Business Support during Coronavirus click [here](#)

From: Craig Milligan

Sent: 12 July 2021 12:50

To: James Cross <James.Cross@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Ryefields Farmhouse, Oak Tree Lane, Woodgate, Chichester, West Sussex, PO20 3GU - AL/81/21/PL

Planning Application Reference: AL/81/21/PL

Proposal: Demolition of existing building & erection of 5 No houses comprising 1 No 4-bed detached, 2 No 4-bed link detached & 2 No 3-bed detached houses with associated access & parking (resubmission following AL/72/19/PL). This site is in CIL Zone 1 & is Zero Rated.

Address: Ryefields Farmhouse, Oak Tree Lane, Woodgate, Chichester, West Sussex, PO20 3GU

Dear James,

Environmental Health has no objection in principle to the above proposal, however the following matters must be considered.

Contaminated Land

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:

1. A Preliminary Risk Assessment which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; potentially unacceptable risks arising from contamination at the site.
2. A Site Investigation Scheme, based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. Based on the Site Investigation Scheme and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A Verification Report providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a long-term monitoring and maintenance plan for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Unexpected contamination

If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Construction – Small Developments

The development shall be carried out in accordance with the 'Arun District Council Construction Code of Practice: For small developments in Arun', available from:

<https://www.arun.gov.uk/download.cfm?doc=docm93jjm4n12193.pdf&ver=12201>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Noise from Railway line

The proposed development shall not begin until a scheme for protecting the proposed dwellings from noise and vibration from the railway lines adjacent to the proposed development has been submitted to and approved in writing by the Local Planning Authority.

Any works which form part of the scheme approved by the Local Planning Authority shall be completed before any permitted dwelling is occupied unless an alternative period is agreed in writing by the Local Planning Authority

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Internal Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

External Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the external noise levels within the curtilage of residential units will conform to the 'Design criteria for external noise' upper guideline value of 55 dB $L_{Aeq,T}$ as specified within section 7.7.3.2 of BS 8233:2014.

Guidance on sound insulation and noise reduction for proposed developments shall be submitted to and approved in writing by the Local Planning Authority. The work specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Thank you for your consultation,

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

