

From: Simon Davis
Sent: 31 August 2018 14:11

Subject: FW: Planning Consultation on: AL/86/18/PL

Dear Richard,

Please note that we have had drainage engineer comments which although states no objection, there is a comment to say that:

"It should also be noted that the site is within a groundwater source protection zone, therefore sufficient treatment of water to the ground will have to be demonstrated."

I have queried this and been told that It will need to be demonstrated that the SuDS scheme provides sufficient reduction in pollution concentrations before the water is allowed to infiltrate. This can be achieved via ensuring water is held for a set duration before it is allowed to infiltrate, by passing water through various medium such as permeable paving, etc

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maitravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.