

From: Simon Davis
Sent: 31 August 2018 14:13
To: Planning.Responses
Subject: FW: RE: Planning Consultation on: AL/86/18/PL

2nd Engineers comments.

From: Laura Gibbons
Sent: 31 August 2018 13:21
To: Simon Davis
Subject: RE: RE: Planning Consultation on: AL/86/18/PL

Hi Simon,

It will need to be demonstrated that the SuDS scheme provides sufficient reduction in pollution concentrations before the water is allowed to infiltrate. This can be achieved via ensuring water is held for a set duration before it is allowed to infiltrate, by passing water through various medium such as permeable paving, etc.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 29 August 2018 09:55
To: Laura Gibbons
Subject: RE: Planning Consultation on: AL/86/18/PL

Hi,

What do you mean by?

"It should also be noted that the site is within a groundwater source protection zone, therefore sufficient treatment of water to the ground will have to be demonstrated."

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.