

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

To register to receive notifications of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: Craig Hatton [REDACTED]

Sent: Friday, September 20, 2024 9:46 AM

To: Planning <Planning@arun.gov.uk> [REDACTED]

Subject: Network Rail response to AL/89/24/OUT

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

OFFICIAL

Good Morning

Please find attached Network Rail’s objection to the planning application ref: AL/89/24/OUT

Also attached are our standard informatives related to ASPRO engagement as referred to in the letter



Craig Hatton MA MRTPI
Senior Town Planner
Network Rail Property (Southern)
Office Address: 1 Puddle Dock, London, EC4V 3DS


For Town Planning advice, please complete this Instruction Form and submit to  following which your project will be assigned to a Town Planner who will be in contact.

Advance Notice of Leave:

At Network Rail we work flexibly – so whilst it suits me to email now, I do not expect a response or action outside of your own working hours

The content of this email (and any attachment) is confidential. It may also be legally privileged or otherwise protected from disclosure.

This email should not be used by anyone who is not an original intended recipient, nor may it be copied or disclosed to anyone who is not an original intended recipient.

If you have received this email by mistake, please notify us by emailing the sender, and then delete the email and any copies from your system.

Liability cannot be accepted for statements made which are clearly the sender's own and not made on behalf of Network Rail.

Network Rail Infrastructure Limited registered in England and Wales No. 2904587, registered office Network Rail, Waterloo General Office, London, SE1 8SW.



Network Rail
1 Puddle Dock
London
EC4V 3DS

Via email only

Network Rail Consultation Response

To	Leanne Richardson – Arun District Council
Application Reference	AL/89/24/OUT
Location	Land at Woodgate Nurseries
Date	19/09/2024

Dear Leanne

Thank you for providing Network Rail with the opportunity to make comment on the above application.

Network Rail is the statutory undertaker responsible for maintaining, operating and developing the main railway network and its associated estate. Our aim is to protect and enhance the railway infrastructure, therefore any proposed development which is in close proximity to the railway line or could potentially affect Network Rail's specific land interests will also need to be carefully considered.

Network Rail have reviewed the submitted documents with the application and **object** to the application.

Reasons

- The proposed development will cause an increase of usage at Woodgate level crossing which is located immediately to the north of the site. The crossing is already extremely busy with traffic flowing over the crossing constantly and additional flows from the proposed development will further exacerbate this. The amenities serving the development are north of the railway and it is likely that most vehicle and pedestrian users will engage the level crossing which brings with it increased risk of safety and queuing due to barrier down time. The development fails to propose any mitigation for pedestrians or vehicles to minimise use and safety risk.
- The Transport Assessment has based its calculations using survey data taken in June 2023 which precedes the additional stopping and non-stopping services running on the West Coastway line to and from Barnham station, introduced in June 2024. These additional services will increase the time that the level crossing barrier is down for. This will impact on congestion and queuing times and thorough assessment of the service changes is required.
- The application also relies on the A29 re-alignment being brought forward to reduce local congestion and traffic over the level crossing. The alignment is somehow from being fully funded and deliverable and therefore cannot be relied upon as a reasonable form of mitigation. Should the re-alignment not materialise there will be no alternative means of reducing traffic over the level crossing. Network Rail does not consider that the A29 re-alignment to be a suitable form of mitigation to reduce the traffic over the level crossing.

In addition to the above, Network Rail has standard informatives that are needed to be adhered to in order to ensure no impact on the safe and efficient running of the railway. Engagement is required with Network Rail's Asset Protection Team (ASPRO).

I trust the above is clear however please do not hesitate to contact me if further discussion is required on any of the points raised above.

Craig Hatton MRTPI
Senior Town Planner



Asset Protection Informatives for works in close proximity to Network Rail's infrastructure

The developer must ensure that their proposal, both during construction and after completion does not:

- encroach onto Network Rail land
- affect the safety, operation or integrity of the company's railway and its infrastructure
- undermine its support zone
- damage the company's infrastructure
- place additional load on cuttings
- adversely affect any railway land or structure
- over-sail or encroach upon the air-space of any Network Rail land
- cause to obstruct or interfere with any works or proposed works or Network Rail development both now and in the future

Network Rail strongly recommends the developer complies with the following comments and requirements to maintain the safe operation of the railway and protect Network Rail's infrastructure.

Future maintenance

The applicant must ensure that any construction and subsequent maintenance can be carried out to any proposed buildings or structures without adversely affecting the safety of/or encroaching upon Network Rail's adjacent land and air-space. Therefore, any buildings are required to be situated at least **2 metres (3m for overhead lines and third rail)** from Network Rail's boundary.

This requirement will allow for the construction and future maintenance of a building without the need to access the operational railway environment. Any less than **2m (3m for overhead lines and third rail)** and there is a strong possibility that the applicant (and any future resident) will need to utilise Network Rail land and air-space to facilitate works as well as adversely impact upon Network Rail's maintenance teams' ability to maintain our boundary fencing and boundary treatments. Access to Network Rail's land may not always be granted and if granted may be subject to railway site safety requirements and special provisions with all associated railway costs charged to the applicant.

As mentioned above, any works within Network Rail's land would need approval from the Network Rail Asset Protection Engineer. This request should be submitted at least 20 weeks before any works are due to commence on site and the applicant is liable for all associated costs (e.g. all possession, site safety, asset protection presence costs). However, Network Rail is not required to grant permission for any third-party access to its land.

Plant & Materials

All operations, including the use of cranes or other mechanical plant working adjacent to Network Rail's property, must at all times be carried out in a "fail safe" manner such that in the event of mishandling, collapse or failure, no plant or materials are capable of falling within 3.0m of the boundary with Network Rail.

Drainage

Storm/surface water must not be discharged onto Network Rail's property or into Network Rail's culverts or drains except by agreement with Network Rail. Suitable drainage or other works must be provided and maintained by the Developer to prevent surface water flows or run-off onto Network Rail's property. Proper provision must be made to accept and continue drainage discharging from Network Rail's property; full details to be submitted for approval to the Network Rail Asset Protection Engineer. Suitable foul drainage must be provided separate from Network Rail's existing drainage. Soakaways, as a means of storm/surface water disposal must not be constructed within **20 metres** of Network Rail's boundary or at any point which could adversely affect the stability of Network Rail's property. After the completion and occupation of the development, any new or exacerbated problems attributable to the new development shall be investigated and remedied at the applicants' expense.

Scaffolding

Any scaffold which is to be constructed within 10 metres of the railway boundary fence must be erected in such a manner that at no time will any poles over-sail the railway and protective netting around such scaffold must be installed. The applicant/applicant's contractor must consider if they can undertake the works and associated scaffold/access for working at height within the footprint of their property boundary.

Piling

Where vibro-compaction/displacement piling plant is to be used in development, details of the use of such machinery and a method statement should be submitted for the approval of the Network Rail's Asset Protection Engineer prior to the commencement of works and the works shall only be carried out in accordance with the approved method statement.

Fencing

In view of the nature of the development, it is essential that the developer provide (at their own expense) and thereafter maintain a substantial, trespass proof fence along the development side of the existing boundary fence, to a minimum height of 1.8 metres. The 1.8m fencing should be adjacent to the railway boundary and the developer/applicant should make provision for its future maintenance and renewal without encroachment upon Network Rail land. Network Rail's existing fencing / wall must not be removed or damaged and at no point during or post construction should the foundations of the fencing or wall or any embankment therein, be damaged, undermined or compromised in any way. Any vegetation within Network Rail's land boundary must not be disturbed. Any fencing installed by the applicant must not prevent Network Rail from maintaining its own fencing/boundary treatment.

Lighting

Any lighting associated with the development (including vehicle lights) must not interfere with the sighting of signalling apparatus and/or train drivers' vision on approaching trains. The location and colour of lights must not give rise to the potential for confusion with the signalling arrangements on the railway. The developers should obtain Network Rail's Asset Protection Engineer's approval of their detailed proposals regarding lighting.

Noise and Vibration

The potential for any noise/vibration impacts caused by the proximity between the proposed development and any existing railway should be made aware to the future occupiers of the site. It must also be assessed in the context of the National Planning Policy Framework which holds relevant national guidance information.

The current level of usage may be subject to change at any time without notification including increased frequency of trains, night-time train running and heavy freight trains. The appropriate building materials should be used to reduce any potential noise disturbance from the railway.

Vehicle Incursion

Where a proposal calls for hard standing area/parking of vehicles area near the boundary with the operational railway, Network Rail would recommend the installation of a highways approved vehicle incursion barrier or high kerbs to prevent vehicles accidentally driving or rolling onto the railway or damaging lineside fencing.

Landscaping

Any trees/shrubs to be planted adjacent to the railway boundary these shrubs should be positioned at a minimum distance greater than their predicted mature height from the boundary. Certain broad leaf deciduous species should not be planted adjacent to the railway boundary as the species will contribute to leaf fall which will have a detrimental effect on the safety and operation of the railway. Network Rail wish to be involved in the approval of any landscaping scheme adjacent to the railway. Any hedge planted adjacent to Network Rail's boundary fencing for screening purposes should be so placed that when fully grown it does not damage the fencing or provide a means of scaling it. No hedge should prevent Network Rail from maintaining its boundary fencing. If required, Network Rail's Asset Protection team are able to provide more details on which trees/shrubs are permitted within close proximity to the railway.

Existing Rights

Whilst not a planning matter, we would like to remind the applicant of the need to identify and comply with all existing rights on the land. Network Rail request all existing rights, covenants and easements are retained unless agreed otherwise with Network Rail.

Property Rights

notwithstanding the above, if any property rights are required from Network Rail in order to deliver the development, Network Rail's Property team will need to be contacted.

If you would like to discuss any of the above, please contact your local Network Rail's Asset Protection team:



To identify your route, please use the link: <https://www.networkrail.co.uk/running-the-railway/our-routes>