

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 31 August 2021 09:38
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Subject: AL/90/21/DOC -- Land West of Fontwell Avenue 1 Fontwell Avenue Eastergate PO20 3RU

Hi Maria,

I have had a look at this in Sarah's absence. I have the following comments on Condition 3:

- The surface water drainage layout drawing notes state infiltration between $1.66 \times 10^{-6} \text{m/s}$ and $1.226 \times 10^{-4} \text{m/s}$. The calculations use $5.633 \times 10^{-5} \text{m/s}$, please provide justification as to why this rate has been used in calculations.
- Please can further details of the previous ground investigations be provided. E.g. dates, dimensions of test pts, locations of test pits, etc.
- Please can finish and formation levels be labelled on plan.
- Please can the type of aggregate be labelled on the construction detail drawing.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF