

From: Fiona Fitzgerald
Sent: 01 May 2014 12:08
To: Simon Davis
Subject: FW: Planning Consultation on: AW/114/14/PL

Dear Simon,

I have assessed the Acoustic Noise Report submitted with this application, reference KR03715, dated 2nd April 2014. I would be grateful if you would ask the applicant to clarify the following:

1. To specify the exact measurement positions used during the test, specifically where the measurements were taken, and what the tester considered the nearest noise sensitive premises to be. I consider that the nearest noise sensitive premises to be 72 Rose Green Road which is much closer than the 17.9m distance used in the report, and would therefore have an impact on the overall results.
2. To specify whether the fact that two units are to be installed has been incorporated into the calculations.
3. To specify whether the background noise assessment was taken with or without the current chiller/air conditioning units being operational, and what the operational hours of these current units are known to be.

Regards

Fiona Fitzgerald

From: Matthew Kennett
Sent: 15 April 2014 15:06
To: Fiona Fitzgerald
Subject: FW: Planning Consultation on: AW/114/14/PL

From: Sam Humphries
Sent: 15 April 2014 15:03
To: Pollution
Subject: FW: Planning Consultation on: AW/114/14/PL

C/N: 203324

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 14 April 2014 09:35

To: EH Planning Consultations
Subject: Planning Consultation on: AW/114/14/PL

To: **Environmental Health - Graham Evans/Sarah Meeten**

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order
2010 (as amended)
Planning Permission**

APPLICATION NO: **AW/114/14/PL**

Registered: 14th April
2014

Site Address: Co-operative 68 Rose Green Road Bognor Regis PO21 3EQ

Grid Reference: 490372 99347

Description of Works: Instalment of two new external cold rooms to be positioned within the rear yard area.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 15-MAY-14.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Regards
Planning Officer

consultee_email
