

Karen Garner

From: Graham Evans
Sent: 26 June 2012 10:52
To: Planningecons
Cc: Janice Chapman

Subject: FW: Planning Consultation on: AW/120/12/

It is unclear from the information submitted which specific external unit is proposed. The Ground Floor Mechanical Services Layout Plan suggests that the proposed condenser produces 48dBA, it is not clear whether this represents a sound pressure or a sound power level. Ideally a sound pressure level at a given distance from the unit should be provided.
 No information is provided on existing (background) noise levels (it is noted that there does not appear to be existing plant or other noise making plant in the vicinity), or on proposed hours of operation of the condenser (noise produced is less likely to be significant if use is restricted to bank opening hours). Please also clarify whether there is residential accommodation above the application site (submitted plans indicate not), otherwise the nearest noise sensitive premises appears to be approximately 12m from the condenser unit?

Graham Evans
 Senior Environmental Health Officer
 Arun District Council
 01903 737694

From: Sam Humphries
Sent: 26 June 2012 08:48
To: Graham Evans
Subject: FW: Planning Consultation on: AW/120/12/

[C/N: 193253](#)

Sam Humphries Administrative Assistant, Corporate Resources Arun District Council Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF Internal: 37393 External: +44 (0) 1903 737500 Fax: 01903 730442 E-mail: sam.humphries@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: planningecons@arun.gov.uk [<mailto:planningecons@arun.gov.uk>]
Sent: 25 June 2012 11:01
To: EH Planning Consultations
Subject: Planning Consultation on: AW/120/12/

*******DO NOT CHANGE OR DELETE THIS EMAIL*******

To: Environmental Health - John Green

NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Ord 2010 (as amended)
Planning Permission

APPLICATION AW/120/12/

NO:

Registered: 15th May
 2012

Site Address: Barclays Bank Plc 6 Nyetimber Lane Bognor Regis PO21 3HG

Grid Reference: 490542 99135

Description of Works: Installation of 1 no. new condenser unit

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this

26/06/2012

email
by 14-JUN-12.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:
www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mrs J Chapman who can be contacted on telephone number 01903 737657.

Regards
Planning Officer

consultee_email
