Nicola Spencer

[redacted]vations

From: [redacted]
Sent: 29 September 2014 17:49
To: Janice Chapman
Cc: N INGRAM
Subject: 53 Kingsway, Craigwell Estate

Janice,

Further to your emails, please find revised drawings attached.

Changes are as follows:-

i. Block plan and site plan corrected with reference to position of neighbouring houses.
ii. Garage extension moved back to be in line with existing house front peirs.
iii. Areas of brickwork shown hatched on elevations.
iv. Velux windows raised so bottom of glass 1700mm above finished floor level. These windows will therefore not provide views down onto neighbouring properties whether opened or closed.

With reference to windows, it is intended on having all new powder coated aluminium windows throughout, however tis can be changed to UPVC is preferred.

We would also welcome the opportunity to speak at the committee meeting and trust that a time slot can be allocated for this.

Please let me know if you require any further details.

Regards,

Steve
A&B Design

ARUN DISTRICT COUNCIL AW/201/14/HH