

Sign up to our newsletter [here](#)



From: Kathryn Welch

Sent: 27 October 2020 10:52

To: 'Philip Woolger' [REDACTED]

Subject: RE: 8 Fernhurst gardens.

Dear Mr Woolger,

Many thanks for these items, this are far more comprehensive.

Just a few more items that I require in order to request the sign off for you project, these are;

- The porch is slightly too large, to be covered by PD rights the maximum allowance is 3m² and your proposal currently measures at 3.84m² can you adjust this on plans 010 and 003.
- Can I have confirmation of the height to the eaves for the extension, either via email or included within a plan,
- Can you confirm that the extensions will be built of materials to match the existing property. You've noted a concrete slate tile on the roof of the extension; do you already have these on the existing house or can you amend to something similar to the existing,
- Can you confirm the proposed hardstanding for 2-3 cars will be built of either porous materials or will drain off to water permeable area within the site, again just a written confirmation will suffice.

Many thanks,

Kathryn

Kathryn Welch
Planning Officer, Planning Department



T: 01903 737789
E: kathryn.welch@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Philip Woolger [REDACTED]
Sent: 26 October 2020 15:38
To: Kathryn Welch <Kathryn.Welch@arun.gov.uk>
Subject: 8 Fernhurst gardens.

Kathryn hope I find you well, and I hope you are the person handling our project 8 Fernhurst Gardens.

Attached our my changed plans showing dimensions as I think you requested and also a site plan of garage to building.

If these are not correct please do not hesitate to contact me.

rgds.

P.K.Woolger.