




From: Ian Brewster
Sent: 29 May 2013 11:24
To: Cian Cronin
Subject: RE: Application AW/40/12/

Cian,

We require a statement from the applicant detailing the measures they are to take to protect the Eucalyptus from damage caused by the development. I refer to the BS 5837 (2012) and particular to the protection of the ground at a radial distance of 12 x main stem diameter (at 1.5m) to be fenced off and remain sacrosanct throughout the development i.e. no encroachment into this Root Protection Zone. No storage of associated liquids or heavy material which could leach into or cause damage to the soil structure. Protection measures should be written as a planning condition or some similar enforceable alternative (?).

Ian

From: Cian Cronin
Sent: 29 May 2013 11:10
To: Ian Brewster
Subject: FW: Application AW/40/12/

Ian,

Sorry to hassle you.

Could you draft me a few lines about the application mentioned below please?

Thanks,

Cian

From: Cian Cronin
Sent: 23 May 2013 09:15
To: Ian Brewster
Subject: Application AW/40/12/

Ian,

Hope you're well.

I received the attached rep letter to the above application. The respondent is concerned about a TPO eucalyptus in the front garden. The TPO was served last year.

The proposal is a moderate 1.5 metre extension to the front, and will presumably have some influence on the root area of the tree.

Could you have a quick look at the application and send me some comments please?

Thanks,

Cian