

[REDACTED]

From: Angel Whitworth [REDACTED]
Sent: 02 April 2019 17:05
To: Charlotte Easton <Charlotte.Easton@arun.gov.uk>
Cc: Martyn White <Martyn.White@arun.gov.uk>; Daniel Vick <Daniel.Vick@arun.gov.uk>
Subject: Re: 54 Kingsway AW/44/19/DOC

Hello Charlotte,

Thank you for your message.

The Metsawood cladding sample I supplied is heat-treated but it does not yet have a coating. The sample you have is heat-treated natural wood in the form that it would be supplied to our builders. According to Metsawood this would have a 30-year service life. Once the cladding is in place we would then have it treated with a clear wood preserver which is the coating referred to in the section of the brochure I supplied. This would then give it a 60 year service life. (Please see below)

Sincerely
Annaliesa

30 Year Service Life

Uncoated ThermoWood-D (pine) exterior cladding can provide a 30-year desired service life.

If coated, over the life of the product, ThermoWood-D will have a 60-year desired service life, providing the coating is maintained in-line with the coating manufacturer recommendations over the service life of the product*.

From: Charlotte Easton <Charlotte.Easton@arun.gov.uk>
Sent: 02 April 2019 13:59
To: 'Angel Whitworth'
Cc: Martyn White
Subject: RE: 54 Kingsway AW/44/19/DOC

Dear Ms Whitworth,

Thank you for the revised sample submitted to the office today.

Within the details of the product you have supplied there is a paragraph relating to a 30 or 60 year life service life, the 60 year is coated. Could you please confirm if the sample you have provided is a 'coated' sample or not?

Many Thanks

Charlotte

From: Angel Whitworth [REDACTED]
Sent: 02 April 2019 13:04
To: Martyn White <Martyn.White@arun.gov.uk>
Cc: Charlotte Easton <Charlotte.Easton@arun.gov.uk>; Daniel Vick <Daniel.Vick@arun.gov.uk>
Subject: 54 Kingsway AW/44/19/DOC

Dear Martyn,
I hand delivered the new sample of wood cladding to your office yesterday.
I hope you will have received it by now.
I look forward to hearing your comments.
Many thanks
Annaliesa Whitworth

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
