

From: Simon Davis
Sent: 16 July 2018 11:43
To: 'Angus Eitel' [REDACTED]
Subject: RE: AW/71/18/HH

Hi Angus,

I've just looked again at the response this morning and have also just spoken with Mark. There is a part of the response that Mark gave that requires a couple of small changes to the reports which I need you to action and then send in the updated docs. The relevant text is as follows:

I have two outstanding concerns which ought to be easily overcome, but nonetheless should be reflected in a revised AIA/AMS:

- I request confirmation that the area of 'No-dig' is undisturbed and adequately protected (it lies within the RPA) at the outset and immediately prior to installation of the cellweb construction layer. The ground protection measures necessary to achieve this should be determined by the project arboriculturist, with reference to the recommendations made in B55837:2012, section 6.2.3.

- Paragraph 8.1 of the AIA report should be amended so that it does not support the stripping of soil within the 'Nodig' area and explicitly states such practice is confined only to the verge outside the curtilage of the property.

I will still write this up for Committee and report the changes as a report update if the revised docs come back later than this Thursday .

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, [Arun District Council](#) |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 13 July 2018 09:47
To: Angus Eitel [REDACTED]
Subject: FW: AW/71/18/HH

FYI. Objection now lifted.

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, [Arun District Council](#) |
Location: Planning, First Floor, Arun Civic Centre, Maltrovers Road, Littlehampton, BN17 5LF

Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.