



From: Amber Willard
Sent: 25 April 2019 08:54
To: Planning Scanning
Subject: FW: AW/79/19/HH - 24 ABeckets Avenue, Aldwick, Bognor Regis.

Please upload as planning correspondence for AW/79/19/HH

From: Chris Moore 
Sent: 25 April 2019 08:29
To: Amber Willard
Cc: 'roy penny'
Subject: AW/79/19/HH - 24 ABeckets Avenue, Aldwick, Bognor Regis.

Dear Amber,

I write on the above application currently under consideration.

I notice that the drainage engineers have asked for a full investigation of the surface water drainage provision for the development because there is a watercourse to the rear of the site.

It should be noted that the proposed surface water drainage for the additional 11 m2 in roof area added will be taken to a new soakaway (1.0 m3 capacity below the invert level of the entry pipe) to the front of the property.

This is located a significant distance away from the 'watercourse' and as such with the minimal increase in area should be deemed acceptable. I would be grateful if these comments could be included in with the application.

Please contact me if you have further queries on this subject.

Kind regards,

Chris Moore

BSc (Hons), C.Build E MCABE
Sussex Building Consultancy Limited
3 Northcote Road
BOGNOR REGIS
PO21 5LZ
