



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
A/109/20/RES

Our ref
PLAN-036490

Date
15/12/2020

Dear Sir/Madam,

Proposal: Approval of reserved matters following outline consent A/99/17/OUT for 175 No dwellings & associated infrastructure. This application may affect the setting of a listed building, may affect the character & appearance of the Angmering Conservation Area & falls within Strategic Site SD9, CIL Zone 1 (Zero Rated).

Site: A/109/20/RES: - Land South of Water Lane, Angmering, BN16 4EJ.

Thank you for your letter dated 15/09/2020.

Southern Water would not recommend approval of layout, until the applicant demonstrates that the standoff distance for public water distribution main is to be maintained.

The comments in our response dated 29/09/2020 remain unchanged and valid.

For any queries please contact us at:

Yours faithfully,

Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

[illegible]