

Amanda Scholes | Receptionist, Department, Arun District Council | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](http://www.arun.gov.uk/CIL)



Save the environment - think before you print.

From: Ian Stocks [REDACTED] **On Behalf Of** FRS Water and Access

Sent: 06 August 2020 15:49

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Planning consultation - A/110/20/RES Land South of Water Lane Angmering

FAO: Michael Eastham

Dear Michael,


Evidence will also be required that there is sufficient access width for a fire appliance to access the site in accordance with the requirements of Approved Document – B: B5 section 13 Vehicle access. The driveway will need to be sufficiently wide enough to allow a fire appliance to gain access minimum width of 3.7 metres and 3.1 metres through a gate (AD-B Vol. 1 Table 13.1) and capable of withstanding 12 to 17 tonne axial weight.

Regards

Ian Stocks
Water & Access manager

Water and Access Office
West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB

Living Our Values Every Day



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
