

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to www.arun.gov.uk/planning and click on Local Planning Application Finder

Sign up to our newsletter [here](#)



From: Ian Stocks [REDACTED] **On Behalf Of** FRS Water and Access

Sent: 29 June 2021 16:25

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Planning consultation - A/110/21/PL BMW House Chandlers Garage Ltd Water Lane Angmering BN16 4EH

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

FAO: Michael Eastham

Dear Michael,


Having viewed the Planning Application no. A/110/21/PL, evidence is required showing that all parts of all dwellings are within 45 metres of a fire appliance or a dry riser outlet. This is a requirement of Approved Document – B (AD-B) Volume 1 2019 edition: B5 section 13. Any areas not within the requirements of AD-B volume 1 section 13 will need to be mitigated by the installation of domestic sprinkler or water mist systems complying with BS9251 or BS8458 standards.

Regards

Ian Stocks
Water & Access manager

Ian Stocks – Water and Access Manager
Water and Access Office
West Sussex Fire and Rescue Service West Sussex County Council
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB

Living Our Values Every Day



LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.
