

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 10 October 2017 08:39
To: Planning Scanning
Subject: FW: Planning Consultation on: A/114/17/PL

From: Paul Cann
Sent: 09 October 2017 11:51
To: Planning.Responses
Subject: RE: Planning Consultation on: A/114/17/PL

Land drainage consent will be required for any alteration to the existing watercourse.

Bearing in mind the existing flooding issues in this vicinity, it is imperative that the proposals do not make things worse. Betterment should be sought where possible.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

Sent: 20 September 2017 17:34

Subject: Planning Consultation on: A/114/17/PL

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL
Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

APPLICATION **A/114/17/PL**

NO:

Registered: 19th June
2017

Site Address: Highway Outside Hangleton Nursery Hangleton Lane Ferring
BN12 6PP

Grid Reference:

Description of Works: To widen a section of Hangleton Lane adjacent to the vehicle storage compound to ease access onto the site for transporter vehicles. This application is also within the parish of Ferring.

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 07-SEP-17.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number [REDACTED]

Regards
Planning Officer

consultee_email

