

From: Thomas Callaway
Sent: 02 October 2015 14:56
To: Planning.Responses
Subject: RE: Planning Consultation on A/115/15/DOC

The drainage design is to be equivalent to the Swanbourne Park development, utilising the same system of private soakaways extending to the gravel strata.

The condition for surface water drainage may be discharged based on the submitted section view of the private soakaways and the proposed percolation rates.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716019 | E-mail: Thomas.Callaway@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 18 September 2015 11:03
To: Thomas Callaway
Subject: Planning Consultation on A/115/15/DOC

To: Engineers (Fluvial Flooding)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION A/115/15/DOC

NO:

Registered: 27-AUG-15

Site Address: Former Pound Nursery Roundstone Lane Angmering

Description of Application for approval of matters reserved by condition

Works: impused under A/167/14/PL relating to conditions 4, 13, 14, 18, 20 & 23 for protection of retained trees, programme of archaeological work, ecological mitigation report, foul water sewerage disposal, surface water drainage & storage of refuse & recycling bins.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditons relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 2nd October 2015.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr N Crowther who can be contacted on telephone number 01903737500 Ex 37839.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
