

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
A/115/15/DOC
Our Ref
PLAN-011647
Date
06/11/2015

Dear Sirs,

Proposal: Application for approval of matters reserved by condition imposed under A/167/14/PL relating to conditions 4, 13, 14, 18, 20 & 23 for protection of retained trees, programme of archaeological work, ecological mitigation report, foul water sewerage disposal, surface water drainage & storage of refuse & recycling bins.


Site: Former Pound Nursery, Roundstone Lane, Angmering, BN16 4AL.
A/115/15/DOC

Thank you for your letter of 23/10/2015.

We regret that Southern Water cannot recommend discharge of foul condition as the drawing submitted does not comply with Sewer for Adoption standards.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the discharge condition for surface water disposal.

Yours sincerely



Developer Services