



I have reviewed the submitted noise assessment and I am happy for condition 5 to be discharged as the assessment does not indicate that the development will cause a noise problem to nearby residents.

However, section 6.2.3 of the report states that the steel roller shutter doors will have to remain closed during daytime operations. The noise calculations and conclusions of the report have been based on the doors being kept shut to contain the noise so it is imperative that this happens at all times when noisy work is taking place. Failure to keep the doors closed will lead to noise breakout and increases the likelihood of complaints from neighbours and action under Statutory Nuisance legislation by this department.

Joanne Lewis

Please note that I work part time and my normal working days are Wednesday – Friday.


Joanne Lewis

Senior Environmental Health Officer,
Environmental Health



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



To: **Environmental Health - Planning consultation**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No:	A/117/20/DOC
Registered:	3rd August 2020
Site Address:	Roundstone Van Centre Roundstone Lane Angmering BN16 4AT
Description of Works:	Approval of details reserved by condition imposed under ref A/73/19/PL relating to Condition No 5 - noise assessment.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **19th August 2020**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Mrs A Gardner

Planning Case Officer- Arun District Council



PLCONDOC (ODS) 2020