

Julie Grieves

From: Amanda Scholes on behalf of Planning.Responses
Sent: 25 September 2018 08:32
To: Julie Grieves
Subject: FW: Further Information Required on Your Ref: PP-07216782 Our Ref: A/126/18/PL

Follow Up Flag: Follow up
Flag Status: Flagged

Sent: 24 September 2018 13:49
To: Planning.Responses
Subject: RE: Further Information Required on Your Ref: PP-07216782 Our Ref: A/126/18/PL

Dear Sirs,

With reference to your letter dated 24th September, I confirm that the proposed hardstanding will be covered with a permeable surface discharging into the ground in accordance with Approved Document H Paragraph 2.9 – 2.13 (Pervious Paving) of the Building Regulations.

Regards

Rex Adams

rja Planning & Building
Consultants Ltd