

**WEST SUSSEX COUNTY COUNCIL
INFRASTRUCTURE CONSULTATION**

DATE: 27/11/2009

FROM: Jamie Brown **TO: Arun District Council**
FAO: J. Smith

SUBJECT: A/133/09/A- One internally illuminated box sign.

Angmering Manor Hotel, High Street, Angmering, West Sussex, BN16 4AG

CONSULTATION DATE: 16/11/2009

RECOMMENDATION:

Advice	☒	Modification	☐	More Information	☐
Objection	☐	No Objection	☐	Refusal	☐

S106 contribution: £ N/A

The Highway aspect of this application has been dealt with in accordance with the Development Control Scheme protocol for small scale proposals which include up to 5 residential units or extensions to single units accessed from roads that do not form part of the Strategic Road Network (SRN). As such the comments provided by Local Development should be considered to be advice only, with respect to this planning application.

This response comprises of the views of West Sussex County Council. The highways and architectural implications of this proposal have been considered and these views are incorporated within this response.

Highways

This proposal has been considered by means of a desktop study, using the information and plans submitted with this application, in conjunction with other available map information.

I refer to your consultation in respect of the above planning application and would provide the following comments.

Upon inspection of the plans, it does not appear that this illuminated box sign is in a location where it could obstruct the highway. From an inspection of the plans it would appear that the sign overhangs the pavement, therefore a Highway license will be required before it is erected. Provisionally, there would be no highway objection to this sign, providing its luminance levels do not exceed 1000 cd/m² and a licence is acquired from WSCC.

INFORMATIVE

Before the commencement of any operation, the applicant is advised to contact West Sussex County Council (Tel no: 01243 642105) to obtain a Section 177 Licence under the Highways Act 1980 to cover any structure that overhangs the highway.

Conservation Architecture

The County Architect has no concerns with this application.

Jamie Brown
Local Development