




LTR/08021/39/JW

22 August 2017

Mrs D Johnson
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Dear Mrs Johnson

ST MARGARET'S CHURCH HALL REFURBISHMENT, ANGMERING. A/147/17/PL

Further to your letter dated 16th August 2017, please find attached the PDF of the required additional information. This is:

1. Block plan at a scale of 1:500, please find drawing 08021PL(00) 014 Site Block Plan.
2. A fee has been posted to you offices please confirm receipt of this.
3. Please find drawing 08021 WD (21) 22 Proposed Gas Electric Meter attached with this letter, this shows all elevations of the meter cabinet.
4. The air intake hood was made specifically for this project therefor the manufacturer details are only what has been provided by the ventilation contractor. The Hood is made from a galvanised steel, 315mm in diameter and approximately 350mm tall.

We trust the above and attached information are sufficient to validate the application, if however you have any further queries please contact us.

Yours sincerely



Lee Evans Partnership LLP

chartered architects and planning consultants

