

Conservation Area Advisory Committee

Meeting Date : 4th September

Ref	Description	Address	Design award
X A/147/17/PL	Creation of brick built electric meter cabinet, insertion of 1 No. wall mounted gas metre into eastern elevation & new air intake duct in eastern slope of roof. This application may affect the setting of a listed building & affects the character & appearance of the Angmering Conservation Area.	St Margarets Church Hall Arundel Road ANGMERING BN16 4JS	
Comments: No objection in principle			
Suggested Conditions: A more sympathetic approach to the placement of the meter box so it does not protrude above flint wall. New intake duct to be painted black			
			
			