

From: Brian Banister [REDACTED]
Sent: 14 October 2025 14:20
To: Planning.Responses
Subject: Arun Conservation Area Advisory Panel comments on applications

Follow Up Flag: Follow up
Flag Status: Flagged

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.


Hello,

The **Arun Conservation Area Advisory Panel** wish the following comments to be taken into consideration in the determination of the applications:

**A/150/25/HH and A/151/25/L - The Vestry Cottage, Arundel Road, Angmering
No Objection**

It is considered that the proposed works will not harm the character or appearance of the conservation area.

Given the historic importance of the building, the Panel considered that rather than replace the larger of the kitchen windows with a single double glazed pane it would be more in keeping to introduce one or two vertical glazing bars, to be more sympathetic with the glazing pattern in the remainder of the elevation.



Kind regards,
Brian Banister MRTPI(Rtd), GradDiplConsAA
On behalf of ACAAP