

From: Martyn White
Sent: 18 January 2019 09:52
To: Planning.Responses
Cc: Anita Gardner
Subject: A/157/18/DOC

A/157/18/DOC

The application relates to the finishes to be used for the supporting piers which are located on the front elevation of the property. I note that the proposal is to use two different materials; brick and black stained timber cladding. Such materials seem to be acceptable in particular instance.

It is therefore considered that as long as the brick matches that already approved by the LPA, that the condition may be discharged.

Martyn White | Principal Conservation Officer, Planning Policy, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37717 | External: +44 (0) 1903 737717 | E-mail: Martyn.white@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.