

From: Bruce Taunton <Bruce.Taunton@arun.gov.uk>
Sent: 27 November 2019 12:37
To: Andrew Wood <Andrew.Wood@arun.gov.uk>
Subject: A/157/19/PL - Quiet Water, Angmering

Hi Andrew,

I have looked at the technical content for the ramp and consider the proposals meet the requirements for wheelchair users. Ramp lengths appear to be approximately 9.0m and the fall height is around 760mm placing it at the limits of the 1 in 12 allowable slope.

Kind regards

Bruce Taunton

Bruce Taunton | Principal Structural Engineer, Arun District Council | Location: 1st Floor, Arun Civic Centre, Maltravers Road,
Littlehampton, BN17 5LF

Internal: 37816 | External: +44 (0) 1903 737816 | E-mail: bruce.taunton@arun.gov.uk
Working in partnership with Chichester, Horsham & Worthing District Councils

Visit our web sites at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.