

[REDACTED]

[REDACTED]

[REDACTED]








[REDACTED]

[REDACTED]

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Our priorities...

 Improving the wellbeing of Arun	 Delivering the right homes in the right places	 Supporting our environment to support us	 Fulfilling Arun's economic potential	 Our core foundations	 
--	---	---	---	--	--

Connect with us: [Facebook](#) | [X](#) | [Instagram](#)

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 26 January 2026 15:11
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: David Easton <David.Easton@arun.gov.uk>
Subject: A/159/25/PL

Further to Environmental Health's previous response, please could it be amended to require the acoustic assessment to include potential noise from the proposed facility as well as the air source heat pumps and air conditioning units. The acoustic assessment should include take account of hours/days of use and predicted noise levels from use of the facility given the residential dwellings located adjacent.

As per paragraph 5.4.2 of Planning Noise Advisory Document Sussex 2023 it is recommended that a Noise Management Plan is submitted covering issues such as hours and days of use, community liaison, complaints procedures and preventing unauthorised use.

Regards

Fiona Fitzgerald
Senior Environmental Health Officer

Environmental Health

T: 01903 737674

E: fiona.fitzgerald@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

My normal working hours are 08.30 – 14.30 Monday to Friday

Sign up to our newsletter [here](#)

