

Peter Cleveland

From: Graham Evans
Sent: 08 February 2012 11:46
To: Peter Cleveland
Subject: RE: LAMB ANGMERING - EXTRACT DETAILS A/164/11

Hi Peter,

No information on how this figure is arrived at? Nevertheless I think this will be acceptable within the proposed operating hours.

Regards
 Graham

From: Peter Cleveland
Sent: 07 February 2012 12:04
To: Graham Evans
Subject: FW: LAMB ANGMERING - EXTRACT DETAILS A/164/11
Importance: High

Hi Graham

Further to our last discussion on this site, the applicants have submitted some greater detail regarding the noise level of the proposed extraction system. It appears to give greater detail and gives details of distances to the nearest noise sensitive point of 15metres at 32dB(A).

Please could you let me know if this detail would satisfy the previous concerns regarding this ventilation system.

Regards
 Peter

<u>Peter Cleveland</u> MSc Senior Planner, Planning Department, <u>Arun District Council</u> Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF Internal: 37631 External: +44 (0) 1903 737631 E-mail: Peter.Cleveland@arun.gov.uk Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.
--

From: Liz Galloway [REDACTED]
Sent: 07 February 2012 11:41
To: Peter Cleveland
Cc: 'Martin Newbon'; 'Lee Newbon'; 'ricardo field'
Subject: FW: LAMB ANGMERING - EXTRACT DETAILS A/164/11
Importance: High

Dear Peter
 Please find additional information in regard to Extract as received from the supplier. Hope this is satisfactory
 Thanks and regards
 Liz

From: James Williams [REDACTED]
Sent: 06 February 2012 15:54
To: Liz Galloway
Cc: Martin Newbon; Lee Newbon; 'Tracy'
Subject: FW: LAMB ANGMERING


Importance: High

Hi Liz,

Martin forwarded over the information we required this morning – please find relevant documents attached

Regards,

James Williams
Cucina Commercial Limited
Stoken Farm
Steventon
Basingstoke
Hampshire
RG25 3BD



James

Please forward to Liz Galloway - Hopefully the EHO will look on this favourably!

Regards

Ray

Peter Cleveland

From: Graham Evans
Sent: 25 January 2012 09:04
To: Peter Cleveland
Cc: Anna Appleton
Subject: RE: The Lamb A/164/11

Follow Up Flag: Follow up
Flag Status: Red

Peter,

I could not open one of the attachments? There is insufficient information to enable determination of the level of noise impacting upon the nearest "sensitive receptor". Ideally the sound pressure level produced by the system as a whole should be given, but the sound pressure level (dB(A)) produced by the fan and attenuation (sound reduction) provided by the (two) duct silencers would give some idea of likely noise emission.

It is noted that it is not intended that the ventilation system will operate after 22.30 hours if this is accepted as a condition it is possible that any (noise) impact will not be significant.

Anna will respond in respect of odour control, however it does not appear that they intend to provide any?

Regards

Graham

-----Original Message-----

From: Peter Cleveland
Sent: 24 January 2012 15:38
To: Graham Evans; Anna Appleton
Subject: FW: The Lamb A/164/11

Hi Graham and Anna

Please find attached further some further information relating the ventilation extract system proposed for The Lamb, Angmering (Planning Ref A/164/11). Your consultation required some further information regarding noise and odour control measures which they have looked to address. I am not sure if the attached would be sufficient to satisfy your concerns.

Please could you let me know your thoughts on the attached information.

Many thanks
Peter

Peter Cleveland MSc | Senior Planner, Planning Department, Arun District Council |
Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37631 | External: +44 (0) 1903 737631 | E-mail: Peter.Cleveland@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

-----Original Message-----

From: Liz Galloway [REDACTED]
Sent: 19 January 2012 16:07
To: Peter Cleveland
Cc: 'lnewbon'; 'ricardo field'; 'Martin Newbon'
Subject: FW: The Lamb A/164/11

Dear Peter

Please find attached details of the Extract System as requested by Environmental

Health. If you require any further information please do not hesitate to let me know.
The details of the supplier are below fyi.

Many thanks
Liz

-----Original Message-----

From: James Williams [redacted]
Sent: 18 January 2012 11:23
To: lizgalloway@caldotec.co.uk
Subject: FW: The Lamb


Morning Liz,

Please see attached documents regarding extraction, as you will see I need some info from Martin re opening hours etc .

Regards,

James Williams
Cucina Commercial Limited
Stoken Farm
Steventon
Basingstoke
Hampshire
RG25 3BD

Tel:
Fax:
Email:
Web:
Projects Div:



James

Attached 'draft' copy of the response to the EHO document.

The Lamb needs to advice Items 1 a, b, c and d and Item 10 c.

Regards

Ray

Peter Cleveland

From: Liz Galloway [REDACTED]
Sent: 19 January 2012 16:07
To: Peter Cleveland
Cc: 'Inewbon'; 'ricardo field'; 'Martin Newbon'
Subject: FW: The Lamb A/164/11

Attachments: Cucina The Lamb EHO document.doc; Garvin Baffle Filters.pdf; Woods 50JM 20 4 6 performance data.doc; _Certification_.txt



Cucina The Lamb EHO document.d... Garvin Baffle Filters.pdf (1 M... Woods 50JM 20 4 6 performance ... _Certification_.txt (205 B)

Dear Peter

Please find attached details of the Extract System as requested by Environmental Health. If you require any further information please do not hesitate to let me know. The details of the supplier are below fyi.
Many thanks
Liz

-----Original Message-----

From: James Williams [REDACTED]
Sent: 18 January 2012 11:23
To: lizgalloway@caldotec.co.uk
Subject: FW: The Lamb


Morning Liz,

Please see attached documents regarding extraction, as you will see I need some info from Martin re opening hours etc .

Regards,

James Williams
Cucina Commercial Limited
Stoken Farm
Steventon
Basingstoke
Hampshire
RG25 3BD

Tel:
Fax:
Email:
Web:
Projects Div: wv



James

Attached 'draft' copy of the response to the EHO document.

The Lamb needs to advice Items 1 a, b, c and d and Item 10 c.

Regards

Ray



Julie Grieves

From: Peter Cleveland
Sent: 01 December 2011 12:45
To: Julie Grieves
Subject: FW: Emailing: 3255-2 Extract System THE LAMB.pdf, 11045 NEWBON The Lamb Angmering PROPOSED R1 A1.pdf, 11045 THE LAMB Design & Access Statement Windows Fire Escape Kitchen Extract R1.pdf, 11045 THE LAMB HERITAGE STATEMENT Windows Fire Escape Kitchen Extrac

Attachments: 3255-2 Extract System THE LAMB.pdf; 11045 NEWBON The Lamb Angmering PROPOSED R1 A1.pdf; 11045 THE LAMB Design & Access Statement Windows Fire Escape Kitchen Extract R1.pdf; 11045 THE LAMB HERITAGE STATEMENT Windows Fire Escape Kitchen Extract R1.pdf



3255-2 Extract System THE LAMB..he Lamb Angmerin. Design & Access... HERITAGE STATEM..

Peter Cleveland BSc MSc | Senior Planner, Planning Department, Arun District Council
| Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37631 | External: +44 (0) 1903 737631 | E-mail: Peter.Cleveland@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

-----Original Message-----

From: Liz Galloway [mailto:lgalloway@arun.gov.uk]
Sent: 01 December 2011 12:24
To: Peter Cleveland
Subject: Emailing: 3255-2 Extract System THE LAMB.pdf, 11045 NEWBON The Lamb Angmering PROPOSED R1 A1.pdf, 11045 THE LAMB Design & Access Statement Windows Fire Escape Kitchen Extract R1.pdf, 11045 THE LAMB HERITAGE STATEMENT Windows Fire Escape Kitchen Extract R1

Dear Peter
Please find revised drawings, D&A & Heritage Statement for Application A/166/11
This adds extract details and two more windows to be replaced on the rear elevation.
Thanks and regards
Liz Galloway

Your message is ready to be sent with the following file or link attachments:

3255-2 Extract System THE LAMB.pdf
11045 NEWBON The Lamb Angmering PROPOSED R1 A1.pdf
11045 THE LAMB Design & Access Statement Windows Fire Escape Kitchen Extract R1.pdf
11045 THE LAMB HERITAGE STATEMENT Windows Fire Escape Kitchen Extract R1.pdf

Note: To protect against computer viruses, e-mail programs may prevent sending or receiving certain types of file attachments. Check your e-mail security settings to determine how attachments are handled.



Julie Grieves

From: Liz Galloway [redacted]
Sent: 28 November 2011 15:24
To: Julie Grieves
Subject: RE: Request for further information on Your Ref: N/A Our Ref: A/164/11/
Attachments: 11045 The Lamb Angmering LOCATION AND BLOCK A3 L.pdf

Hi

Hope this is clearer. I've had to put the FF plan on the block so that I can show the windows concerned.

Thanks

Liz

From: Julie Grieves [mailto:Julie.Grieves@arun.gov.uk]
Sent: 28 November 2011 11:09
To: Liz Galloway
Subject: RE: Request for further information on Your Ref: N/A Our Ref: A/164/11/

Mrs Galloway,

Is it possible to remove all the internal walls from the block plan. Its best to just have the outline of the building showing the position of the works. It makes it clearer for members of the public.

Regards

Julie Grieves | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
 Internal: 37448 | External: +44 (0) 1903 737711 | E-mail: julie.grieves@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Liz Galloway [redacted]
Sent: 28 November 2011 10:04
To: Planning.Responses
Subject: RE: Request for further information on Your Ref: N/A Our Ref: A/164/11/

Dear Mrs Grieves

Further to our discussion. Please find location & block plan which prints to scale on A3.

Thanks

Liz Galloway

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 25 November 2011 17:30
To: lizgalloway@caldotec.co.uk
Subject: Request for further information on Your Ref: N/A Our Ref: A/164/11/

<http://www.arun.gov.uk>

NLPG UPRN 100062237016

DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

NLPG UPRN 100062237016
DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

No virus found in this message.

Checked by AVG - www.avg.com

Version: 10.0.1411 / Virus Database: 2092/4043 - Release Date: 11/27/11

Julie Grieves

From: Liz Galloway [REDACTED]
Sent: 28 November 2011 08:40
To: Planning Responses
Subject: RE: Request for further information on Your Ref: N/A Our Ref: A/164/11/
Follow Up Flag: Follow up
Flag Status: Completed

Details of the extract system will follow as soon as they are to hand. I believe Mr Cleveland may accept the application on this basis and I will forward the block plan to you. Could you confirm this is OK?

Thanks

Liz

Liz Galloway

Caldotec Ltd

Timbers Lodge
 41 Willowhayne Ave
 East Preston
 West Sussex
 BN16 1PL

*Architectural Design Services
 Health & Safety Consultancy for the Construction Industry
 Disabled Access Auditing*

members of The Business Interchange, Arundel - www.tbi-arundel.co.uk

Proud members of

Checkatrade.com
 Where reputation matters

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 25 November 2011 17:30
To: [REDACTED]
Subject: Request for further information on Your Ref: N/A Our Ref: A/164/11/

<http://www.arun.gov.uk>

NLPG UPRN 100062237016
 DX 57406 Littlehampton

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

