

Charlotte Burrows

From: Peter Cleveland
Sent: 13 February 2012 10:17
To: Planning.Responses
Subject: FW: Planning Application A/164/11 The Lamb, Angmering
Could the below email please be acknowledged as a consultation response.

Peter

<u>Peter Cleveland</u> MSc Senior Planner, Planning Department, <u>Arun District Council</u> Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk  Save the environment - think before you print.

From: Anna Appleton
Sent: 26 January 2012 11:48
To: Peter Cleveland
Cc: Graham Evans
Subject: Planning Application A/164/11 The Lamb, Angmering

Peter

I note that they only intent to install baffle filters which are deigned to remove grease, with no plans for any additional odour control. However, I have spoken to Roy Robinson who is responsible for the installation of the kitchen ventilation system and he stated that the pub will be used for traditional pub food. The impact assessment for the premises indicates only low level of odour control should be required providing the pub provides traditional pub food and not high levels of fried food or other types of cuisine.

As such the filtration suggested should be adequate, providing the applicants can confirm the type of cooking to take place at the premises.

Regards,

Anna Appleton
Senior Environmental Health Officer
Arun District Council
