

Amanda Scholes | Receptionist, Department, Arun District Council | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at www.arun.gov.uk **Error! Hyperlink reference not valid.**



Save the environment - think before you print.

From: Anita Gardner <Anita.Gardner@arun.gov.uk>

Sent: 05 February 2020 12:48

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: FW: Planning Consultation on A/165/19/DOC

Please scan as consultee response

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk



Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Carol Reynolds <Carol.Reynolds@arun.gov.uk>

Sent: 02 February 2020 20:21

To: Anita Gardner <Anita.Gardner@arun.gov.uk>

Subject: FW: Planning Consultation on A/165/19/DOC

Environmental Health:
Noise.

I refer to the Noise Impact Assessment prepared by Venta Acoustics, 24th October 2019, Report Number VA2987.191024.NIA. The Report does not provide sufficient information for this Department to make reasoned judgements upon the suitability of the development.

The Department would require field measurements of specific noise activities in the industrial units **surrounding** the site and in particular the length, duration and intensity of noisy activities occurring at SG Tanks, and Thatcher Motors car body repair shop. We would further require greater detail on the attenuation claimed to be provided by the orientation and layout of the site and why a 3m acoustic barrier would only be required to the south of the site. We would also suggest that the acoustic consultant base their analysis on worst case scenarios such as 10dB attenuation being provided by an open window and on the lower background noise experienced during the daytime assessed period (Table 4.2). The Report would also benefit from consideration of the cumulative effective of similar noisy operations occurring simultaneously on either the same or other immediately surrounding sites.

On this basis Environmental Health would recommend no discharge of Condition 4 in this case.

From: planning.responses@arun.gov.uk <planning.responses@arun.gov.uk>
Sent: 22 November 2019 18:04
To: EH Planning Consultations <EHPlanningConsultations@arun.gov.uk>
Subject: Planning Consultation on A/165/19/DOC

To: Environmental Health - Planning consultation

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: A/165/19/DOC

Registered: 21-NOV-19

Site Address: The Laurels Dappers Lane Angmering BN16 4EN

Description of Works: Approval of details reserved by condition imposed under ref A/74/18/OUT relating to Condition Nos 4 - acoustic, 5 - external lighting, 7 - contamination, 12 - hedgerows, 14 - surface water drainage, 15 - discharge of flows, 16 - SuDs and 18 - watercourse or culvert.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 6th December 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
