

From: Michael Eastham
Sent: 11 December 2020 10:32
To: Planning Scanning
Subject: FW: A/166/20/DOC - Manor Nursery, High Street, Angmering

Please scan and upload onto Ocella the email below from the applicant confirming that we have an extension of time to determine discharge of condition application **A/166/20/DOC** until **Tuesday 15 December 2020**.

Thanks,

Michael

Michael Eastham
Principal Planning Officer,
Planning Department

T: 01903 737772
E: michael.eastham@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Rebecca Hoad [REDACTED]
Sent: 11 December 2020 09:33
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Cc: Chris Barker [REDACTED]
Subject: RE: A/166/20/DOC - Manor Nursery, High Street, Angmering

Michael,

Please refer to my email below dated 8 December 2020 where I have already suggested and agreed to an extension of time until Tuesday 15 December 2020.

We look forward to hearing from you soon.

Kind Regards,

Rebecca Hoad MSc Town Planning
Planner

ECE Planning

We have now successfully attained planning permission for our fourth scheme for Shoreham Port. Read more [here](#).



Brooklyn Chambers, 11 Goring Road, Worthing, West Sussex, BN12 4AP.

Privacy/Confidentiality Statement
www.eceplanning.com

ECE Planning Limited, Registered in England No 07644833, Registered Office Amelia House, Crescent Road, Worthing, West Sussex BN11 1QR.

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 10 December 2020 17:41
To: Rebecca Hoad [REDACTED]
Cc: Chris Barker [REDACTED]
Subject: RE: A/166/20/DOC - Manor Nursery, High Street, Angmering

Dear Rebecca,

Please could I have an extension of time to determine discharge of condition application **A/166/20/DOC** to **Tuesday 15 December 2020**.

Kind regards,

Michael

Michael Eastham
Principal Planning Officer,
Planning Department

T: 01903 737772
E: michael.eastham@arun.gov.uk

Arun District Council, Civic Centre, Maltrovers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Rebecca Hoad [REDACTED]
Sent: 08 December 2020 17:13
To: Michael Eastham <Michael.Eastham@arun.gov.uk>; [REDACTED] Paul Cann
<Paul.Cann@arun.gov.uk>
[REDACTED]
Subject: RE: A/166/20/DOC - Manor Nursery, High Street, Angmering
Importance: High

Dear Michael, Laura and Paul,

Further to Laura's email dated 16 November 2020, please find attached to this email and via the below Dropbox link the following information which seeks to address the comments raised:



- By pass Separator Information
- Calculations
- Network Areas Plan
- Proposed Drainage Strategy
- Drainage Maintenance Plan
- Construction Details
- Drainage Maintenance Manual V2.

Please also see below CEP's answers in red responding directly to the questions raised.

Please could you confirm as soon as possible that the information provided is sufficient to discharge Conditions 6, 21 and 22?

Michael, we would be happy to agree an extension of time to allow re-consultation with Laura and Paul. We would suggest an initial extension of time until Tuesday 15 December 2020.

I look forward to hearing from you.

Kind Regards,

Rebecca Hoad MSc Town Planning
Planner

ECE Planning

We have now successfully attained planning permission for our fourth scheme for Shoreham Port. Read more [here](#).



Brooklyn Chambers, 11 Goring Road, Worthing, West Sussex, BN12 4AP.

Privacy/Confidentiality Statement

www.eceplanning.com

ECE Planning Limited, Registered in England No 07644833, Registered Office Amelia House, Crescent Road, Worthing, West Sussex BN11 1QR.

From: Michael Eastham <Michael.Eastham@arun.gov.uk>

Sent: 16 November 2020 13:22

To: Rebecca Hoad

Cc: Chris Barker

Subject: FW: A/166/20/DOC - Manor Nursery, High Street, Angmering

Importance: High

Rebecca,

Please see the email below which is the consultation response from the ADC Drainage Engineers to discharge of condition application **A/166/20/DOC** relating to Manor Nursery, High Street, Angmering.

I look forward to receiving your reply.

Kind regards,

Michael

Michael Eastham
Principal Planning Officer,
Planning Department

T: 01903 737772

E: michael.eastham@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



From: Laura Gibbons [REDACTED]
Sent: 16 November 2020 11:07
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Cc: Paul Cann <Paul.Cann@arun.gov.uk>
Subject: Re: A/166/20/DOC - Manor Nursery, High Street, Angmering

Hi Michael,

Apologies for not being able to look at this sooner, we are swamped. Different Arun working day for me this week.

We do not recommend discharge of these conditions at this time.

I have the following comments:

1. The impermeable areas plan supplied does not clearly show the areas draining to each soakaway. E.g. the areas draining to soakaways 8 and 9 are poorly defined. Please can the applicant supply a better impermeable areas plan which clearly shows the areas draining to each soakaway and which areas have had 10% urban creep allowance applied. 60_Network Areas Plan has now been updated for clarity and the drainage areas for SA 8 and 9 is now more clearly defined. The plan also now shows which areas have Urban Creep of 10% applied to them in the key.
2. Please detail invert and cover levels of gullies and ACO drains. 102_E Drainage has now been updated to include the requested details.
3. Some pipes appear to terminate without connections. For example where are the pipes upstream of N1 2.000 connecting to/from? This was a technical error with the drawing layers and has now been rectified.
4. Please provide details of the proposed bypass separators and how these will meet the requirements for hazard mitigation indices. Please see attached data sheets and Declaration of Performance.
5. It is unclear how the pipes that are supposed to be able to pass above soakaway 1 will in reality do this. They are draining surface features, i.e. ACO and gullies, and are meant to pass above the top of the crate which is at 14.6mAOD and then within 1m connect into a pipe that has an upstream invert level of 13.943. Please detail how this is supposed to work especially given some of these connections are not via manholes. The network has been slightly rearranged now in this area and also more details have been included to make it clear how this area works. This has all been checked and there will be no issues with the performance of the network or constructing what is proposed.
6. All pipes must achieve 1m/s velocity at full bore. The surface water system will remain private and is not being offered for adoption. Sewers for Adoption requires a velocity of 1 m/s, however for a private system BSEN 752 and Building Regulations Part H apply and require a minimum velocity of 0.75 m/s. The velocity of the system will determine the depths of the pipework, as a higher velocity will increase a lot of the gradients, this will increase the depth of the system and subsequently increase the depth of excavation during construction needlessly. The system has been designed using a minimum velocity of 0.75 m/s which is acceptable based on policy and relevant regulations.
7. SA4 has a maximum water level of 16.575, this is greater than the cover level stated on the drawings. The calculation details for SA 4 are different to those on plan. Please correct so that they are consistent. Cover level updated with calculations.
8. The calculation details for SA 7, SA8, and SA9 are different to those on plan. Please correct so that they are consistent. Calculations updated.
9. Construction detail drawings need to be provided, as per our checklist. Please see 502_Construction Details.
10. A maintenance manual needs to be provided. Attached.

Please re-consult us once further information has been supplied.

Kind regards,

Laura Gibbons

Engineer, Adur & Worthing Councils



Website: www.adur-worthing.gov.uk

Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA



On Mon, 16 Nov 2020 at 09:07, Michael Eastham <Michael.Eastham@arun.gov.uk> wrote:

Hi Laura and Paul,

Please could I have your consultation response to discharge of condition application **A/166/20/DOC** relating to Manor Nursery, High Street, Angmering by 5.00pm tomorrow (**Tuesday 17th November 2020**)?

Kind regards,

Michael

Michael Eastham

Principal Planning Officer,

Planning Department



T: 01903 737772

E: michael.eastham@arun.gov.uk

Arun District Council, Civic Centre, Mallravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please send it back to us, and immediately and permanently delete it. Do not use, copy or disclose the information contained in this message or in any attachment. Whilst every care has been taken to check this e-mail for viruses, it is your responsibility to carry out checks upon receipt.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
