



**Site Address: Manor Nursery, Angmering**

**Client: The Civil Engineering Practice**

**Date of Test: 24/06/19**

**BRE 365 Soakage Test Results**

**Hole ID.....TP6 (test 1)**

**Dimensions (LxWxH) (1.9x0.6x2.5)**

**Gravel filled to 0.5mbql**

| Test Time (Minutes) | Water Level (Metres) |
|---------------------|----------------------|
| 0.1                 | 1.51                 |
| 1                   | 2.08                 |
| 2                   | 2.20                 |
| 3                   | 2.28                 |
| 4                   | 2.31                 |
| 5                   | 2.34                 |
| 6                   | 2.36                 |
| 7                   | 2.38                 |
| 10                  | 2.40                 |
| 15                  | 2.45                 |
| 20                  | 2.50                 |
|                     |                      |
|                     | 1000 litres used     |



**Site Address: Manor Nursery, Angmering**

**Client: The Civil Engineering Practice**

**Date of Test: 24/06/19**

**BRE 365 Soakage Test Results**

**Hole ID.....TP6 (test 2)**

| Test Time (Minutes) | Water Level (Metres) |
|---------------------|----------------------|
| 0.1                 | 1.56                 |
| 1                   | 2.13                 |
| 2                   | 2.24                 |
| 3                   | 2.29                 |
| 4                   | 2.31                 |
| 5                   | 2.34                 |
| 6                   | 2.37                 |
| 7                   | 2.39                 |
| 8                   | 2.40                 |
| 10                  | 2.42                 |
| 15                  | 2.47                 |
| 20                  | 2.50                 |
|                     |                      |
|                     | 1100 litres used     |



**Site Address: Manor Nursery, Angmering**

**Client: The Civil Engineering Practice**

**Date of Test: 24/06/19**

*BRE 365 Soakage Test Results*

**Hole ID.....TP6 (test 3)**

| Test Time (Minutes) | Water Level (Metres) |
|---------------------|----------------------|
| 0.1                 | 1.64                 |
| 1                   | 2.01                 |
| 2                   | 2.17                 |
| 3                   | 2.24                 |
| 4                   | 2.28                 |
| 5                   | 2.31                 |
| 6                   | 2.33                 |
| 7                   | 2.35                 |
| 8                   | 2.37                 |
| 9                   | 2.39                 |
| 10                  | 2.41                 |
| 15                  | 2.44                 |
| 20                  | 2.47                 |
| 25                  | 2.50                 |
|                     |                      |
|                     | 1000 litres used     |
|                     |                      |