



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Jon Andrews Ltd
Chilcote
Threals Lane
West Chiltington
West Sussex
RH20 2RF

Your Ref: A/171/17/DOC

Please ask for:

Mrs A Gardner

13 October 2017

Dear Mr Andrews

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Application for approval of details reserved by condition imposed under planning permission
A/184/15/PL relating to conditions 3-visibility splays, 4-details of screen walls and/or fences, 5-
surface water drainage, 9-level survey, 10-landscape scheme, 11-schedule of materials & finishes &
13-location of swallows nests.
Herons Farm Dappers Lane, Angmering,

Notification regarding the above application:

Condition Number 5

Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.

The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.

No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

This condition cannot be discharged on the basis of the submitted information. In order to comply with the condition, the applicant needs to provide the following information for consideration;

1. Winter groundwater monitoring at an agreed time.
2. Winter percolation testing at an agreed time/depth and at the location of any proposed soakage structures.
3. Detailed drainage layout to include levels/pipe diameters/silt traps, etc.

docdeci

4. Construction detail drawing for the associated drainage elements.
 5. Hydraulic calculation to prove that the critical 1 in 100 year storm event + climate change allowance, can be stored on site. Rainwater harvesting facilities are fine to be incorporated but their volume cannot be used as part of the storage calculations.
- Items 1 and 2 are critical to the design.

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning