

[REDACTED]

[REDACTED]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 12 October 2021 12:05
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: A/177/21/DOC – Cresswell Park, Roundstone Lane, Angmering

Please upload onto Ocella the email below which is a further consultation response from **ADC Drainage Engineers** to discharge of condition application **A/177/21/DOC** regarding Cresswell Park, Roundstone Lane, Angmering.

Thanks,

Michael

From: Laura Gibbons [REDACTED]
Sent: 12 October 2021 11:45
To: Stuart Forrester [REDACTED]

[REDACTED]

Subject: Re: Site meeting with ADC Drainage Engineers and CALA Homes Drainage Engineers - Cresswell Park, Angmering

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Stuart,

Good to meet yourself and Kane this morning.

As discussed, I believe the following is required going forward. Please amend if you do not believe the below is an adequate representation of what was discussed.

- A plan showing the pipes which require relaying will be provided to ADC for approval. This plan will be based upon all pipes being required to meet self cleansing velocity of 0.75m/s as agreed upon as a compromise.
- Layout and details for the proposed swales will be supplied to ADC for approval. Swales are proposed around the bund to intercept overland flows.
- CCTV survey of the soakaway crates is to be completed if possible. It may be possible to ascertain crate dimensions from this.
- As a minimum one hand excavation per soakaway location will be required to check soakaway construction, i.e. cover level, crate connections, geotextile, surround material.
- If CCTV survey of soakaway crates cannot establish dimensions greater excavation will be required.

Kind regards,

Laura Gibbons

Engineer, Adur & Worthing Councils



Website: www.adur-worthing.gov.uk

Address: Facilities & Technical Services, Worthing Town Hall, Chapel Road, Worthing, West Sussex, BN11 1HA

