

From: Amanda Scholes on behalf of Planning.Responses
Sent: 03 December 2020 09:19
To: Planning Scanning
Subject: FW: Planning Consultation on: A/179/20/RES
Attachments: JBA 19-283 01 Angmering detailed plots and POS Rev F.pdf; Angmering AIA - Culvert Trees.pdf

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 02 December 2020 11:41
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: Planning Consultation on: A/179/20/RES

Please upload onto Ocella the email below which is a further consultation responds from **ADC Greenspace** to reserved matters application **A/179/20/RES** relating to Land South of Water Lane, Angmering.

Thanks,

Michael

Michael Eastham
Principal Planning Officer,
Planning Department

T: 01903 737772

E: michael.eastham@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

From: Sue Howell <Sue.Howell@arun.gov.uk>
Sent: 02 December 2020 11:36
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: FW: Planning Consultation on: A/179/20/RES

Thanks Michael

I am happy with the information submitted in Dwg JBA 19/283-01 Rev F and Angmering AIA Culvert Trees pdf and that these contain sufficient information and mitigation requirements to be able to approve the landscape detail under A/179/20/RES.

Regards

Sue

Sue Howell
Leisure and Landscape Officer,
Greenspace + Emergency Planning

T: 01903 737943
E: sue.howell@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 02 December 2020 11:19
To: Sue Howell <Sue.Howell@arun.gov.uk>
Subject: FW: Planning Consultation on: A/179/20/RES

Sue,

Further to your consultation response to **A/179/20/RES** for the embankment and culvert on Land South of Water Lane, Angmering, please see the email below and the 2 attachments.

I look forward to receiving your reply.

Regards,

Michael

Michael Eastham
Principal Planning Officer,
Planning Department

T: 01903 737772

E: michael.eastham@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Sparkes, Jessica [REDACTED]
Sent: 02 December 2020 11:02
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Cc: Havis, Sean [REDACTED]
Subject: Planning Consultation on: A/179/20/RES

Hi Michael

The Arb Impact Assessment submitted for the residential scheme covers that area in terms of tree removal – see extract of Pages 32 and 36 attached.

Only two trees are proposed to be removed to facilitate the culvert, T49 (Cat B1 willow) and T50 (Cat C1 willow).

The planting plan for the resi scheme, ref: 19-283-01 rev F (also attached), shows the area in more detail and explains that the banked areas will be seeded.

Kind regards

Jess

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 01 December 2020 16:00
To: Sparkes, Jessica [REDACTED]
Cc: Havis, Sean [REDACTED]
Subject: *EXTERNAL: FW: Planning Consultation on: A/179/20/RES

**EXTERNAL EMAIL WARNING**

Please do not click on LINKS or ATTACHMENTS where you are unsure of its origin. In such cases delete the email.

Jess,

Please see the email below which is the consultation response from **ADC Greenspace** to reserved matters application **A/179/20/RES** relating to the embankment / culvert on Land South of Water Lane, Angmering.

Is there any chance of grass seeding and compensatory planting of trees to replace those trees that are proposed to be removed as they are in the way of the visibility splay?

Kind regards,

Michael

Michael Eastham
Principal Planning Officer,
Planning Department

T: 01903 737772
E: michael.eastham@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Sue Howell <Sue.Howell@arun.gov.uk>
Sent: 01 December 2020 15:45
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: Planning Consultation on: A/179/20/RES

Response to Planning Application

From: Arun District Council Greenspace

Date: 01/12/2020

Application ref: A/179/20/RES

Description: Approval of reserved matters (appearance, layout & scale of access only) following A/99/17/OUT for a culvert & associated access over the Black Ditch providing access to the approved development. This application may affect the setting of a listed building & falls within Strategic Site SD9, CIL Zone 1 (Zero Rated).

Location: Land South of Water Lane Angmering

Determining Authority: Arun DC

Summary recommendation: Any substantial clearance if not mitigated will add to biodiversity net loss and should be mitigated for with the reinstatement of native species within the locale.

Comments

Response

The only information supplied in this application relating to landscape consultation would be found in the Proposed access and general arrangement dwg 46353/2002/020 which annotates an area as *existing trees to be cleared* and *vegetation clearance to existing hedgerows and trees required to facilitate the required junction visibility*.

I would comment that there is no detail for the extent of the clearance required and also no mitigation/reinstatement works detailed.

As a minimum the graded banks will require seeding with suitable for location seed mix to return these back to natural habitat. There should also be a requirement for the removed hedgerow and trees from this location to be mitigated for beyond the visibility splay area to compensate for the removals made.

Recommendation/Conclusion

Any substantial clearance if not mitigated will add to biodiversity net loss and should therefore be mitigated for with the reinstatement of native species within the locale.

Sue Howell

Leisure and Landscape Officer,
Greenspace + Emergency Planning

T: 01903 737943

E: sue.howell@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 11 November 2020 11:49
To: Tree Landscape <Tree.Landscape@arun.gov.uk>
Subject: Planning Consultation on: A/179/20/RES

To: **Parks and Landscapes**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

The Town & Country Planning Act 1990 (as amended)

Town & country Planning (Development Management Procedure) (England) Order 2015 - Article 6

Approval of Reserved Matters Following Outline Approval

Application No: A/179/20/RES
Registered: 4th November 2020
Site Address: Land South of Water Lane Angmering
Grid Reference: 507406 104672
Description of Works: Approval of reserved matters (appearance, layout & scale of access only) following A/99/17/OUT for a culvert & associated access over the Black Ditch providing access to the approved development. This application may affect the setting of a listed building & falls within Strategic Site SD9, CIL Zone 1 (Zero Rated).

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 10th December 2020 . You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website <https://www.arun.gov.uk/development-plan> as can the the leaflet how to respond to planning applications <https://www.arun.gov.uk/planning-application-comments> which deals with material planning considerations.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Michael Eastham

Planning Officer- Arun District Council

Telephone: 01903 737772

Email: michael.eastham@arun.gov.uk

PLCONSULT (CDB) 2020

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

The sender of this e-mail is a member of the Barratt Developments PLC group of companies, the ultimate parent of which is Barratt Developments PLC (company number 00604574). Barratt Developments PLC is registered in England and Wales with its registered office at Barratt House, Cartwright Way, Forest Business Park, Bardon Hill, Coalville, Leicestershire LE67 1UF, together with its principal subsidiaries BDW Trading Limited (03018173), and Wilson Bowden Developments Limited (00948402). Barratt Homes, Barratt London and David Wilson Homes are trading names of BDW Trading Limited. This e-mail message is meant only for use by the intended addressee and may contain privileged and/or confidential information. If you have received this message in error please notify us and remove it from your system. Please view our 'Email Addendum v2.0' at

[//www.barrattcommercialsupport.co.uk/barratt-developments-plc-email-a](http://www.barrattcommercialsupport.co.uk/barratt-developments-plc-email-a) for further details.