

[REDACTED]

From: Clark, Robert [REDACTED]
Sent: 01 November 2021 08:14
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Cc: Harris, Aimee [REDACTED] Roger Spencer <Roger.Spencer@arun.gov.uk>
Subject: RE: Planning Consultation on: A/188/21/DOC

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Hi Michael

The extension of time is agreed.

Kind Regards

Rob

Robert Clark
Land and Planning Director
Persimmon Homes Thames Valley
Persimmon House
Knoll Road
Camberley
GU15 3TQ
[REDACTED]

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 28 October 2021 08:29
To: Clark, Robert [REDACTED]
Cc: Harris, Aimee [REDACTED] Roger Spencer <Roger.Spencer@arun.gov.uk>

Subject: FW: Planning Consultation on: A/188/21/DOC
Importance: High

Hi Rob,

Please could we have an extension of time to determine discharge of condition application **A/188/21/DOC** regarding surface water drainage on Land at Dappers Lane, Angmering to **Friday 12th November 2021**.

Could you also ensure that your drainage engineers submit the information requested by ADC Drainage Engineers in the email below including discharge rates, attenuation basin constructability, maintenance manual and details of any land drainage consent as a matter of urgency.

I am on leave today and tomorrow, but I have copied Roger into this email. Please copy Roger into any emails regarding **A/188/21/DOC**.

Thanks,

Michael

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 26 October 2021 13:53
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: Planning Consultation on: A/188/21/DOC

Dear Michael,

Thank you for re-consulting us. We have the below comments, which are based upon our previous comments. We do not recommend discharge of condition 18, 19 or 21 at this time.

Discharge Rate

As previously stated, at no point did we recommend that the drainage strategy and accompanying information be listed as approved. If discharge is permitted which is based upon the developable area rather than positively drained area then it is possible that proposals will result in an increase in flood risk, and therefore that the development would fail to meet policy requirements. Water which is not positively drained will infiltrate or flow overland and therefore the total rate discharging from the site will be greater than the greenfield rate.

Attenuation Basin Constructability

The sketch provided does not clearly show batter extents. However, one of the sump locations is proposed within the proposed ditch extent. There is currently a culvert here. Furthermore, the additional fence line shown for excavation is shown the other side of the ordinary watercourse. As proposals currently stand it is apparent that it will not be possible to excavate the required depth here without bunding the watercourse and temporarily removing a significant length. This is unacceptable.

The method statement provided includes no details of the proposed batter. Assuming this will be a standard 1:3 it is apparent that there is inadequate room on site to construct proposals with just a batter. For example, proposals are for the impermeable liner to be at circa 13.8m AOD, where existing ground levels are 21.5m. This means an excavation depth of 7.7m, which would require 23m horizontal distance, at most there appears to be approximately 12m available here (ignoring the culvert and 6m distance between batter bank and fence line). Further to the south of the basin, excavation depths of 6m are required, with distances of circa 10m available (ignoring the culvert and 6m distance between batter bank and fence line) for the required 18m horizontal distance.

The method statement identifies that at least 4 no. 6 inch pumps will be required to dewater the excavation 24/7. Even if these are silent, they will require generators which could cause a nuisance to nearby residents.

The maintenance manual identifies a reconstruction cost of £45,634. It is unclear how this cost has been achieved, an initial high level independent review using Spons Civil Engineering and Highways works price book indicates a cost far in excess of this. Please provide a cost breakdown to justify the figure stated. The 100 year service life stated is also unsubstantiated.

It should also be noted that space constraints will be even greater in the future once the development has been constructed and the ordinary watercourse improved.

We therefore believe that the proposals as currently presented are not constructible and would place an unreasonable financial burden upon residents for future reconstruction.

Maintenance Manual

Please include details of the replacement of features at the end of their lifetime. I.e. please indicate lifetimes of elements and the requirements for replacement at the end of their life, e.g. design life of hydrobrakes, crates, impermeable membranes.

Within section 4- cellular storage tanks and attenuation basin details should also include the regular inspection of impermeable liners.

We query the construction cost stated for the attenuation basin.

We also note that an annual maintenance budget of 1% of the costs indicated is very low.

Please detail why riparian maintenance is required and include a plan showing riparian responsibility extent.

OWC Land Drainage Consent

Please supply evidence of land drainage consent.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 26 October 2021 08:34

To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: A/188/21/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: A/188/21/DOC
Registered: 3rd September 2021
Site Address: Land at Dappers Lane Angmering Littlehampton
Description of Works: Approval of details reserved by condition imposed under ref A/76/20/PL relating to Condition Nos 17 - existing & proposed ground levels, 18 - surface water drainage, 19 - maintenance & management of surface water drainage, 21 - discharge flows to watercourses and 22 - foul drainage system

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **16th November 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Michael Eastham

Planning Case Officer- Arun District Council

Telephone: 01903 737772

Email: michael.eastham@arun.gov.uk

PLCOND00 (ODS) 2020

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

We are proud to be an official partner of Team GB.



Persimmon Homes is proud to support local communities. Every year our Community Champions scheme donates £750,000 to local groups and our Building Futures scheme supports young people with donations of over £1 million. [Find out more...](#)



Disclaimer

The information in this email is confidential and may be legally privileged. It is intended solely for the addressee. Access to this email by anyone else is unauthorised. If you are not the intended recipient, any disclosure, copying, distribution or any action taken or omitted to be taken in reliance on it, is prohibited and may be unlawful. If you are not the intended recipient please contact the sender and delete the message.

Our privacy policies for our customers, employees and job applicants are available at <https://www.persimmonhomes.com/corporate/corporate-responsibility/policies>

Persimmon Homes Limited is registered in England number 4108747, Charles Church Developments Limited is registered in England number 1182689 and Space4 Limited is registered in England number 3702606. These companies are wholly owned subsidiaries of Persimmon Plc registered in England number 1818486, the Registered Office of these four companies is Persimmon House, Fulford, York YO19 4FE.

This email has been scanned for viruses and malware, and may have been automatically archived by Mimecast Ltd, an innovator in Software as a Service (SaaS) for business. Providing a **safer** and **more useful** place for your human generated data. Specializing in; Security, archiving and compliance. To find out more [Click Here](#).

As part of its obligations under Part 3, Criminal Finances Act 2017, Persimmon operates a zero tolerance approach to the criminal facilitation of tax evasion.

<https://www.persimmonhomes.com/corporate/media/334191/prevention-of-criminal-facilitation-of-tax-evasion-policy.pdf>