

ADC Drainage Engineers are raising no objection to **Conditions 17, 18 and 19.**

Thanks,

Michael

From: Roger Spencer <Roger.Spencer@arun.gov.uk>
Sent: 29 March 2022 12:07
To: Michael Eastham <Michael.Eastham@arun.gov.uk>
Cc: Paul Cann <Paul.Cann@arun.gov.uk>
Subject: RE: Dappers Lane, Angmering (A/188/21/DOC)

Michael,

Sorry, I meant to say that as soon as Persimmon send over the document with the revised version / date reference, that can be approved too.

Regards,

Roger

From: Michael Eastham <Michael.Eastham@arun.gov.uk>
Sent: 29 March 2022 12:02
To: Roger Spencer <Roger.Spencer@arun.gov.uk>
Cc: Paul Cann <Paul.Cann@arun.gov.uk>
Subject: RE: Dappers Lane, Angmering (A/188/21/DOC)

Dear Roger,

What about **Condition 19?**

Regards,

Michael

From: Roger Spencer <Roger.Spencer@arun.gov.uk>
Sent: 29 March 2022 11:43

To: Michael Eastham <Michael.Eastham@arun.gov.uk>

Cc: Paul Cann <Paul.Cann@arun.gov.uk>

Subject: Dappers Lane, Angmering (A/188/21/DOC)

Dear Michael,

I confirm that I have no objection to Condition 17 (Levels).

I would also confirm that outstanding issues with Condition 18 (surface water drainage) have been satisfactorily resolved and accordingly this can be signed off.

Condition 20 (Completion Report) relates to pre-occupation and so is not an issue at this point.

Conditions 21 (Discharge of flows) & 22 (Foul Drainage) – there is lack of clarity around the actual points of connection in Arundel Road. The connections were made by DTCivils with the Client ICOSA (requisitioned by Persimmon) for dealing with the Persimmon site flows. We are working with Persimmon and ICOSA to resolve the issue.

Regards,

Roger Spencer
Engineering Services Manager, Place

T: 01903 737812

E: roger.spencer@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

