

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 19 October 2021 09:29
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on: A/212/21/DOC

Dear Simon,

Thank you for consulting us on this discharge of conditions application we have the following comments regarding condition 4:

- Please can the applicant submit revised construction detail drawings which show the construction of the permeable block paving in place of the resin bound paving previously proposed.
- It appears that diffusers are proposed, these should be labelled with invert level.
- Formation level of permeable paving should be clearly labelled.
- Please can the applicant confirm whether any further changes beyond surface type and the use of diffusers are included within the latest proposals.

Please reconsult us once this information has been supplied.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 05 October 2021 11:19

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Consultation on: A/212/21/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: A/212/21/DOC

Registered: 4th October 2021

Site Address: Merry England Dappers Lane Angmering BN16 4EN

Description of Works: Approval of details reserved by condition imposed under A/91/18/PL relating to condition 4-surface water drainage.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **19th October 2021**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Mr S Davis

Planning Case Officer- Arun District Council

Telephone: 01903 737874

Email: Simon.Davis@arun.gov.uk

PLCOND00 (ODS) 2020