

[REDACTED]

From: Laura Gibbons <laura.gibbons@arun.gov.uk>
Sent: 07 December 2021 08:15
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: FW: Planning Consultation on: A/212/21/DOC

Hi Simon,

Yes, the plan is now okay.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Simon Davis <Simon.Davis@arun.gov.uk>
Sent: 02 December 2021 11:17
To: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Subject: RE: FW: Planning Consultation on: A/212/21/DOC

Hi Laura,

I have had this plan to revise the diffuser level. Can you confirm they have done what you have asked.

Thanks

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place

T: 01903 737874
E: simon.davis@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil
Sign up to our newsletter [here](#)



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 30 November 2021 15:30
To: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: FW: Planning Consultation on: A/212/21/DOC

Hi Simon,

I've given the latest proposals another review. Due to an explanation provided I no longer require diffusers to be located above 1 in 10 year plus CC event. However, there is an error on the layout, which shows a diffuser unit 1m below the formation level. Which is no good.

Otherwise, the proposals appear okay.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF