

Simon Davis

From: Gary Morris <[REDACTED]>
Sent: 17 December 2024 09:21
To: Simon Davis
Cc: Joshua Reid; Edward Jenkinson
Subject: FW: ASH - Interim Groundwater Monitoring Data

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Simon,

Please see below. Could this please be added to the public record and included with the drainage consultation request to WSCC?

Regards

GARY MORRIS MRTPI
Partner

www.alderking.com



Privacy Policy

By responding to this email or emailing Alder King LLP, your name and contact information may be collected, stored and used by Alder King LLP for the business reason why this information should be collected and stored, then please contact the sender of this email. For information about the delivery of our services and marketing, please review our Privacy Policy.

Confidentiality

This email is confidential and/or legally privileged and intended for the use of the addressee only. If you are not the intended recipient or intended recipient, please advise the sender immediately. The use, dissemination, forwarding, printing or copying of this email is strictly prohibited. Alder King LLP accepts no liability for any loss or damage as a result of the use of this email.

Alder King LLP is a Limited Liability Partnership registered in England and Wales No. OC306796. Registered office: Pembroke House, 15 Pembroke Place, Chichester, West Sussex, PO19 1QH, UK.

From: Chris Lennard <[REDACTED]>
Sent: 16 December 2024 17:12
To: Edward Jenkinson <[REDACTED]>
Subject: RE: ASH - RFP Groundwater Monitoring

CAUTION: This email originated from outside of the organisation. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Hi Eddie,

Below are the updated groundwater measurements following todays' visit.

| Probe ID | Depth (m) | Standing Water Level (m) | | | |
|----------|-----------|--------------------------|------------|------------|------------|
| | | 12/11/2024 | 13/11/2024 | 14/11/2024 | 15/11/2024 |
| WS01 | 4.0m | Dry* | 1.30m | 0.85m | 0.91m |
| WS02 | 4.0m | 2.17m* | 1.66m | 1.03m | 1.15m |
| WS03 | 4.0m | 1.08m* | 0.63m | 0.24m | 0.38m |

* - Water levels measured on day of installation (ie. water levels not reached equilibrium)

Kind regards

Chris Lennard BEng (Hons)
Director

Keeble House, Stuart Way
East Grinstead
West Sussex
RH19 4QA
United Kingdom

*Wishing you a Merry Christmas and Happy New Year!
from everyone at Southern Testing and ST Consult*

