

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Carol Reynolds <Carol.Reynolds@arun.gov.uk>

Sent: 20 April 2020 10:41

To: Anita Gardner <Anita.Gardner@arun.gov.uk>

Cc: Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: A/34/20/DOC - Condition11 - Decentralised renewable Energy

Dear Anita,

Environmental Health: Informative.

I note the proposal for a system of Daiken Air Source Heat Pumps which will be provided at each unit of accommodation. I understand that this form of renewable energy supply, which can include external fans and pumps, has been associated with adverse noise to the detriment of, for example, neighbouring residential units. I would therefore strongly recommend that the Acoustic Report required under Condition 19 of the original Application A/46/19/PL includes investigation of this equipment to assess its likely effect on the acoustic environment and whether this is suitable in this case.

Kind regards

Carol

Carol Reynolds | Senior Environmental Health Officer, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37678 | External: +44 (0) 1903 737678 | E-mail: carol.reynolds@arun.gov.uk Secure E-mail:

creynolds@arun.gcsx.gov.uk Visit Arun's web site at www.arun.gov.uk P Save the environment - think before you print.

Please note my Work Days are Tuesday to Friday