

[REDACTED]

Please scan as correspondence with agent

[REDACTED]

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

[REDACTED]

Dear Mr Sellar,

I have now received the comments of the Environmental Health Officer in respect of condition 16. She has requested submission of the following additional information:

- the CGIR identified an exceedance of lead at 0.10 metres depth and stated that based on the proposed development plan, no remediation was required, however no management of this exceedance is mentioned and no subsequent sampling of the garden areas was undertaken;
- the SGRA concludes that gas protection measures are likely to be required, however no detail is provided.

Please can you let me have receipt of these additional details within the next 2 weeks?

Regards

Anita Gardner

[REDACTED]

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.