

Bronte Welham

From: Amanda Scholes on behalf of Planning.Responses
Sent: 27 April 2018 08:23
To: Planning Scanning
Subject: FW: Planning Consultation on: A/36/18/OUT
Attachments: A_36_18_OUT_SWD.docx

From: Kevin Brook [REDACTED]
Sent: 26 April 2018 15:42
To: Planning.Responses
Subject: Planning Consultation on: A/36/18/OUT

Dear Mrs A Gardner

Please see attached the response for the above Planning Consultation from the WSCC Flood Risk Management team.

Kind Regards

Kevin Brook
Flood Risk Management Engineer
Residents' Services - Highways and Transport
West Sussex County Council

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

**WEST SUSSEX COUNTY COUNCIL
FLOOD RISK MANAGEMENT CONSULTATION**

DATE: 25th April 2018

FROM: Kevin Brook

TO: Arun District Council

FAO: Mrs A Gardner

PLANNING REFERENCE: A/36/18/OUT

LOCATION: Land Off, Arundel Road, Angmering, BN16 4ET

RECOMMENDATION:

Advice	☒	Modification	☐	More Information	☒
Objection	☐	No Objection	☐	Refusal	☐

West Sussex County Council (WSCC), in its capacity as the Lead Local Flood Authority (LLFA), has been consulted on the above proposed development in respect of surface water drainage.

The following is the detailed comments of the LLFA relating to surface water drainage and flood risk for the proposed development and any associated observations, recommendations and advice.

Flood Risk Summary

Current surface water flood risk based on uFMfSW for 30year and 100year events	Low risk
Comments: Current uFMfSW mapping shows the site to be at low risk from surface water flooding. This risk is based on modelled data only and should not be taken as meaning that the site will/will not definitely flood in these events. Any existing surface water flow paths across the site must be maintained. Reason: NPPF paragraph 103 states – ‘When determining planning applications, local planning authorities should ensure flood risk is not increased elsewhere..’ Therefore, a wholesale site level rise via the spreading of excavated material should be avoided.	

Modelled groundwater flood hazard classification	Low risk
Comments: The area of the proposed development is shown to be at low risk from groundwater flooding based on current mapping. This risk is based on modelled data only and should not be taken as meaning that the site will/will not suffer groundwater flooding. Ground water contamination and Source Protection Zones. The potential for ground water contamination within a source protection zone has not been considered by the LLFA. The LPA should consult with the EA if this is considered as risk.	

Records of any historic flooding within the site?	No
Comments: We do not have any records of historic flooding within the confines of the proposed site. This should not be taken that this site has never suffered from flooding, only that it has never been reported to the LLFA.	

Ordinary watercourses nearby?	Yes
Comments: Current Ordnance Survey mapping shows an ordinary watercourses running north west of the site. Local or field boundary ditches, not shown on Ordnance Survey mapping, may exists around the site. If present these should be maintained and highlighted on future plans. Works affecting the flow of an ordinary watercourse will require ordinary watercourse consent and an appropriate development-free buffer zone should be incorporated into the design of the development.	

Future development - Sustainable Drainage Systems (SuDs)

The FRA included with this outline application proposes that attenuation a controlled discharge to the ditch/watercourse would be used to control the surface water runoff from the site.

As indicated by the ADC Drainage Engineer, winter groundwater monitoring should be carried out for the entire site to assess how and where infiltration can be incorporated into the surface water drainage designs.

The current design suggests that a surface water pumping station would be installed on site. Clear evidence should be provided as to the need for a pumped surface water station as this is not a sustainable solution and should only be considered if all other options can be discounted.

Development should not commence until finalised detailed surface water drainage designs and calculations for the site, based on sustainable drainage principles, for the development have been submitted to and approved in writing by the Local Planning Authority. The drainage designs should demonstrate that the surface water runoff generated up to and including the 100 year, plus climate change, critical storm will not exceed the run-off from the current site following the corresponding rainfall event.

Development shall not commence until full details of the maintenance and management of the SUDs system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The scheme shall subsequently be implemented in accordance with the approved designs.

Please note that Schedule 3 of the Flood and Water Management Act 2010 has not yet been implemented and WSCC does not currently expect to act as the SuDS Approval Body (SAB) in this matter.

Kevin Brook
Flood Risk Management Team