



Visit Arun's web site at **Error! Hyperlink reference not valid.**



Save the environment - think before you print.



Please can these plans be added to the application



Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/CIL

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.



Hi Anita,

These are the latest plans that I have seen, including the silt traps... e-mailed direct to me from their engineer. Not from the applicant, or uploaded as far as I am aware.


Sarah Burrow
Engineering Assistant



Thanks Sarah

If the client has no objection, then I have no objection!
Revised plans attached which the client will submit formally with the other info that you have asked for

Cheers
Bob




Hi Bob,

I have raised the silt trap debate with Paul and he is holding firm that silt traps are easier to clean out than the soakaways. I have just had a call from the applicant about the other issues raised and he seemed to have no objection to their inclusion. Otherwise, all fine.

Kind Regards

Sarah Burrow
Engineering Assistant



Hi Sarah

I'm responding on behalf of our client but this is just to hopefully agree the drainage issues with which we are dealing. If we can agree, then the client will respond formally to these and other issues and at least we will have sorted our bit out – hope that's all ok.

1. That's fine and I have lowered the overflow/link pipe.
2. We don't normally include for separate silt traps when we are using concrete ring soakaways, as the soakaways themselves act as silt traps and have access for de-silting if necessary. We don't allow for soakage through the base in the calcs as we assume that they will silt up in years to come.

3. We have not been asked to get involved with the driveway and assume that the architect will deal with this. If this situation changes we will get back to you.
4. Construction details:
 - a) Silt traps – see above. Inspection chambers – see Key on Layout Plan SK4 and Note on IC Detail SK5
 - b) Pipe bed and surround detail added
 - c) Driveway – see above
 - d) Retaining wall – architect/structural engineer to respond separately
5. Client to respond on this as he did earlier.

Hope this is all ok

Kind regards

Bob

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
