

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 13 July 2018 09:36
To: Planning Scanning
Subject: FW: Reserved Matters application: A/38/18/RES - Manor Nursery, High Street, Angmering

From: Michael Eastham
Sent: 11 July 2018 13:11
To: Planning.Responses
Subject: FW: Reserved Matters application: A/38/18/RES - Manor Nursery, High Street, Angmering

[REDACTED]

Thanks,

Michael

From: Laura Gibbons
Sent: 11 July 2018 13:07
To: Michael Eastham
Subject: RE: Reserved Matters application: A/38/18/RES - Manor Nursery, High Street, Angmering

Comments Relating to Surface Water Drainage

A revised surface water drainage scheme has been provided. Which is a move away from the previously proposed permeable paving. Winter groundwater monitoring and infiltration testing will need to be completed to accompany any DOC application to determine the efficacy of these proposals.
Our comments and conditions regarding A/51/14/OUT still apply.
Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

[REDACTED]

Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Michael Eastham
Sent: 09 July 2018 15:52
To: Paul Cann
Subject: FW: Reserved Matters application: A/38/18/RES - Manor Nursery, High Street, Angmering

Hi Paul,

Please could I have a consultation response on Reserved Matters application: A/38/18/RES - Manor Nursery, High Street, Angmering.

Thanks,

Michael