



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
A/38/18/RES

Our ref
PLAN-033602

Date
18/06/2020

Contact:

Dear Sir/Madam,

Proposal: Condition 20.

Site: A/38/18/RES: - Manor Nursery, High Street, Angmering, BN16 4AW.

Thank you for your letter dated 23/07/2019.

The submitted water protection measures is satisfactory to Southern water.

However, the public water main requires a clearance of 6 metres on either side of the water main to protect it from construction works and to allow for future access for maintenance.

No excavation, mounding or tree planting should be carried out within 6 metres of the external edge of the public water main without consent from Southern Water.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website:

Yours faithfully,

Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670